



Shawver WELL COMPANY, INC.
WATER WELL DRILLING AND REPAIRING

P.O. BOX 266

DIAL 319-237-5341

FREDERICKSBURG, IOWA 50630

TEST PUMPING FOR CITY OF CLAYTON

FEBRUARY 2, 1982

TIME	WATER LEVEL IN WELL	GALLONS PER MINUTE
11:10-Start up	120'	102
11:20	120' 6½"	102
11:24	151' 10"	100
11:26	153' 3½"	100
11:29	150' 4"	100
11:32	154' 5"	100
11:33-Shut down		
11:36-Start up	123'	
11:50	162' 2½"	128
11:51	163' 6"	127
11:52	163' 7½"	127
11:53	164' 1"	127
11:59	164' 9"	127
12:04	164' 8½"	128
12:30	164' 7"	128
12:45	164' 2"	130
1:00	164' 2½"	129
1:15	164' 5"	129
1:17	160'	103
1:45	158'	102
2:15-Shut down	157' 7"	102

FEBRUARY 4, 1982

8:45-Start up	120'	102
8:47	152' 9½"	102
8:50	153' 3½"	102
8:55	154' 6"	102
9:00	154' 11"	102
9:05	154' 11½"	102
9:10	155' 10"	102
9:15	156' 4"	102
9:20	156' 6"	102
9:25	156' 8"	102
9:30	156' 8"	102
9:45	156' 10"	102
10:00	156' 10"	102
10:15	157' 3"	103
10:30	157' 3"	103



Shawver

WELL COMPANY, INC.

WATER WELL DRILLING AND REPAIRING

P.O. BOX 266

DIAL 319-237-5341

FREDERICKSBURG, IOWA 50630

-2-

TIME	WATER LEVEL IN WELL	GALLONS PER MINUTE
11:00	157' 3"	103
12:00	157' 8"	103
1:00	157' 4"	103
2:00	157'	102
3:00	157'	102
4:00	157'	102
4:45-Shut down	157'	102
RECOVERY TIME		
4:47-Start up	125'	
4:48	124' 5"	
4:49	124'	
4:50	123' 6"	
4:51	123' 3"	
4:52	123'	
4:53	122' 10"	
4:55	122' 7"	
4:58	122' 4"	
5:03	121' 11"	
5:08	121' 7"	
5:15	121' 5"	
5:30	121' 3"	
5:45	120' 11"	