

57176

Drawdown/Recovery Measurements

Name City of DeWitt

Date ~~2/1/03~~ 3/4/03Location ~~8th Ave & 2nd St.~~

Well No. 7

Barometric Pressure 30.5

Airline Length 350

Time	Time in Minutes S.W.L.	Gauge Reading	Water Level	Drawdown	Pumping Rate of Test Well
		165	185		816
	0	80	270	85	816
	1	60	290	105	812
	2	55	295	110	816
	3	45	303	118	816
	4	43	307	122	816
	5	35	315	130	812
	7	32	318	133	816
	9	32	320	135	816
	11	28	324	139	812
	15	26	324	139	807
	20	21	329	144	807
	25	21	329	144	807
	30	20	330	145	807
	35	20	330	145	807
	40	19	331	146	807
	45	16	334	149	807
	50	16	334	149	807
	60	15	335	150	807
	70	15	335	150	807
	80	14	336	151	802
	90	11	339	154	797
	100	32	318	133	704
	120	33	317	132	704
	150	33	317	132	704
	180	32	318	133	704
	210	32	318	133	710
Sample	240	31	319	134	710
	270	31	319	134	710
	300	31	319	134	710
	6-hr.	30	320	135	704
	7	29	321	136	704
	8	29	321	136	704
	9	28	322	137	704
	10	28	322	137	704
	11	27	323	138	704
	12	27	323	138	699
	13	26	324	139	699
	14	26	324	139	693
	15	25	325	140	693
Sample	16	25	325	140	693
	17	25	325	140	693
	18	24	326	141	693
	19	24	326	141	693
	20	23	327	142	698
	21	23	327	142	698
	22	22	328	143	698
	23	22	328	143	698
	24	22	328	143	693

