


W-7810



MEMBER


# HOEG & AMES, Inc.

WELL CONTRACTORS

WELL SUPPLIES

☆☆☆

LINCOLN, IOWA



Town of Garnaville - Well No. 2

July 6, 1956

<u>TIME</u>	<u>ALTITUDE GAUGE</u>	<u>PUMPING LEVEL</u>	<u>G.P.M.</u>	<u>REMARKS</u>
11:00 A.M.	88	312 B.W.L.		
11:15	15			
11:30	30	330	18	Slight sand
12:00 P.M.	60	328	14	Water clearing
12:30	90		396	Water clearing
12:45	105	327	15	Water temperature 53
1:00	120	328	16	Almost clear
1:30	150	329	17	
2:00	180	329	17	Water clear
2:30	210	329	17	
3:00	240	329	17	Took water sample
3:40	280	329	17	
4:35	335	328	14	
4:50	350	329	17	
5:05	365	329	17	
5:50	410	328	16	
5:55	415	322	10	Cut speed
6:00	420	320	8	
6:45	465	320	8	
6:50	470	320	8	
6:55	475	320	8	
7:00	480	318	6	

D.D.

July 7, 1956

4:00 A.M. 88 312 Ft.

*Replaces - first received -  
 Destroy first one*

*260 min  
 410 min  
 5:50*