

Drilled for Water of Ankeny at Ankeny, Iowa
 250 ft. directly south of existing well, situated in a 90' x 440' tract owned by the Turn,
 Well is located 1/4 miles N-E-S-W and 1/4 miles N-E-S-W from
 about 1/4 mile north of Ankeny, on the west side of the Highway which parallels the F.R.D.M. & Co. Elec. Co. tracks.
 to the 1/4 Section 1/4 Township 1/4 Range

Drilling started Sept. 22nd 1903 Completed Oct. 20th 1903

Well No. _____ Kind of Well Walled Depth 169 Also hole started 13 in

Flaish 8" G. P. M. 250 Static head 170 Drawdown 24

Water was first encountered at 161 in Sand Approx. Acat. _____ Temp. _____

Remarks _____

RECORD OF PERMANENT PIPE					TEMPORARY PIPE	
SIZE PIPE	AMOUNT OF PIPE	DEPTH TO BOTTOM OF PIPE	DEPTH TO TOP OF PIPE	MAKE OF PIPE	SIZE PIPE	AMOUNT
<u>8"</u>	<u>176' 10"</u>	<u>176' 10"</u>	<u>21' above surface</u>			
<u>10"</u>	<u>15</u>	<u>169</u>	<u>There overlies screen with lead seal on top</u>			

Driller _____ From Surface to _____ feet

Driller _____ From _____ feet to _____ feet

Driller _____ From _____ feet to _____ feet

AMOUNT IN FEET	KIND OF SOIL OR FORMATION (BE SPECIFIC)	TOTAL DEPTH FEET
<u>12</u>	<u>Yellow clay</u>	<u>12</u>
<u>21</u>	<u>Gray clay</u>	<u>33</u>
<u>20</u>	<u>Yellow clay</u>	<u>53</u>
<u>15</u>	<u>Blue clay</u>	<u>68</u>
<u>72</u>	<u>Blue clay - sandy</u>	<u>140</u>
<u>12</u>	<u>Sand - fine</u>	<u>152</u>
<u>10</u>	<u>Sand & gravel</u>	<u>162</u>
	<u>Globe Johnson Pump Turbine</u>	
	<u>1 1/2" of 1 1/2" column pipe</u>	
	<u>6 1/2" 9' hole</u>	
	<u>10' 1/2" tail pipe</u>	