

THORPE WELL COMPANY

1903 HULSIZER
ANKENY, IOWA

Drilled for City Water Dept. at Boone

Well is located 100' miles NE-S-W and 20' miles N-E-S-W from # 17 well

in the 1/4 Section 1/4 Township Range

Drilling started 7-10- 1929 Completed 7-12 1929

Well No. 23 Kind of Well Gravel Rock Depth 54' Size hole started 30" in

Finish 30" G. P. M. Static Head Pumping level from surface

Water was first encountered at in Approx. Amt. Temp.

Remarks

(GIVE DETAILS OF PERFORATED PIPE AND SEALS)

| RECORD OF PERMANENT PIPE | | | | | TEMPORARY PIPE | |
|--------------------------|----------------|-------------------------|----------------------|---|----------------|--------|
| SIZE PIPE | AMOUNT OF PIPE | DEPTH TO BOTTOM OF PIPE | DEPTH TO TOP OF PIPE | MAKE OF PIPE | SIZE PIPE | AMOUNT |
| 12" | 50' | 44' | + 6' | 375 well GL. | 36" | 7' |
| | | | | | | |
| | | | | | | |
| 16" | 10' | 54' | 44' | S.S. 60% Johnson 1 1. Northern | | |

Driller Jim Butler From Surface to 54' feet

Driller From feet to feet

Driller From feet to feet

| AMOUNT IN FEET | KIND OF SOIL OR FORMATION (BE SPECIFIC) | TOTAL DEPTH FEET |
|----------------|---|------------------|
| 19' | Brown Sandy soil | 19' |
| 16 | Med sand to gravel | 35' |
| 2' | Blue Clay | 37' |
| 4' | Med sand ^{to} coarse sand | 41' |
| 13' | Fine to coarse gravel with Boulders | 54' |