

# Lynn-Western Company

4430 Commercial Avenue - Omaha, Nebraska

## TEST WELL REPORT

W-36220?

City and State Avoca, Iowa Date October 1, 1975  
Contract City of Avoca Driller Vic Soukup  
Test No. 75-2 Helpers Jim Rentschler  
Static Water Level 12'

### Test Log

0' - 2' Black soil  
2' - 9' Brown silty clay  
9' - 11' Blue clay  
11' - 15' Coarse sand, gravel, & boulders, buff color  
15' - 30'6" Coarse sand, gravel, & boulders, blue color  
30'6" - 38' Blue clay

Size Mud Pit—Length 4' , Width 4' , Depth 3'

### WATER BEARING FORMATION DATA

Depth	Mud Viscosity	Inches Mud Taken from Pit	Drilling Time
11' to 20'	34 Sec.	5"	
20' to 30'6"	34 Sec.	6"	
to			
to			
to			
to			
to			

LOCATION: 85' West of Well #2

REMARKS: Night pump 200 GPM. Electric logged to 36', P-10, R10.