WELL LOG

Feet		Feet	Description
0	to	4	Fill
4	to	6	Black dirt
6	to	17	Yellow clay, gravel
17	to	61	Gray clay
61	to	110	Dark gray clay, pebbles
110	to	127	Gravel, pebbles
127	to	150	Fine - coarse sand
150	to	155	Fine to coarse sand, clay
155	to	156	Gray clay
156	to	159	Fine - coarse sand
	to		
	to		
	to		
	to		
	to		
	to		
	to		
	to		
	to		
	to		
	to		
	to		
	to		

Well Test Data: Static Level 127 ; pumping level 145 after 6 hours pumping at 264 g.p.m.

Length of test 6 hrs. See Well Test Data Sheet Dated

REMARKS:

Well was developed 4 times w/100 lb. P-4 treatment.