



Layne-Western Company, Inc.

WATER SUPPLY CONTRACTORS

705 SO. DUFF AVE.

AMES, IOWA 50010

Phone 515 232-3563

Name of Job Spencer Utilities and Spencer Foods Date 11/22/76

City or Village Spencer, Iowa State Iowa

Well No.: 4 - 76 Drillers: Rich Peisha

Well Location: _____ ft. (____) and _____ ft. (____) of the _____ corner of

Section _____, Twp. _____ (____), Range _____ (____) _____ County.

Otherwise located as 600' East of #102

Work Began: _____ Work Completed: _____ Well Depth: 76'

All measurements made from existing ground level at time well was drilled.

Casing Record:

Amount	Dia.	Wt. or Thickness	Material
<u>56'</u>	<u>16"</u>	<u>3/8" wall</u>	<u>Std. Pipe with Welded joints from 4' above to 56' ground level</u>
_____	_____	_____	_____ with _____ joints from _____ to _____

Screen Record: Type Johnson-Layne

Amount	Dia.	Opening	Material
<u>20'</u>	<u>16"</u>	<u>.075"</u>	<u>stainless steel with Welded joints from 56' to 76'</u>
_____	_____	_____	_____ with _____ joints from _____ to _____

Type of Seal at Bottom Stainless steel plate

Hole Record:

36" inch from 0' to 72'

_____ inch from _____ to _____

Gravel Pack Record:

Amount	Size	Source	From	To
<u>25 yds.</u>	<u>1" Buckshot</u>	<u>Milford Sand & Gravel</u>	<u>4'</u>	<u>72'</u>
_____	_____	_____	_____	_____

Cementing Record: Top 4'

Backfill Record: _____

1-17

Length of test. 4 hrs. See Well Test Data Sheet Dated

REMARKS: