

WELL NO. 5

Owner: City of Wadena, Iowa

Date Drilled: December 10, 1974

Well Log:

0' to 8' Topsoil & Clay
8' to 26' Broken Limerock
26' to 60' Limerock

Comments:

Cased to 27' with 6 inch ID casing equipped with forged steel drive shoe.

Static Water Line (SWL) 33' from ground level and does lower when pumping at the rate of 20 gallons per minute.