

W43160

THORPE WELL COMPANY
 2340 SIXTH AVENUE
 DES MOINES, IOWA

Drilled for State Hospital at Woodward Iowa

Well is located 3 miles N-E-S-W and 1/2 miles N-E-S-W from Woodward Iowa

in the SW 1/4 SW 1/4 Section 13 Township Beaver Range R 27 W

Drilling started 9-9 1925 Completed 9-17 1965

Well No. 2 Kind of Well Ground pack Depth 114' Size hole started 32" in.

Finish 26 G. P. M. 851 Static Head 50' 5" Pumping level from surface 64

Water was first encountered at _____ in _____ Approx. Ann. _____ Temp. 54°

Remarks Well is located on No. 7 test well

(GIVE DETAILS OF PERFORATED PIPE AND SEALS)

RECORD OF PERMANENT PIPE					TEMPORARY PIPE	
SIZE PIPE	AMOUNT OF PIPE	DEPTH TO BOTTOM OF PIPE	DEPTH TO TOP OF PIPE	MAKE OF PIPE	SIZE PIPE	AMOUNT
10"	101'	99'	2' above sl	.365 wall welded Thorpe Everdeer	26	32'
12"	15'	114'	98'	Screen 1/2 X 1 1/2	slat	

Driller Elvin Greene From Surface to _____ feet

Driller Max Smith From _____ feet to _____ feet

Driller _____ From _____ feet to _____ feet

AMOUNT IN FEET	KIND OF SOIL OR FORMATION (BE SPECIFIC)	TOTAL DEPTH FEET
3	Black soil	3
7	Gray clay	10
4	course sand and gravel	14
4	gray clay	18
8	course sand and gravel	26
47	gray clay	73
40	sand and gravel	113
	Boulder at 90 ft	
	Boulder and gray shale	113

