

WRD Exp. (GW)  
April 1966

Well No. 080-16W-163C

### WELL SCHEDULE

U. S. DEPT. OF THE INTERIOR

GEOLOGICAL SURVEY

WATER RESOURCES DIVISION

#### MASTER CARD

Record by D. AARONSON Source of data FILE Date 1/27/67 Map 1:63,360 COUNTY HWY.

State IOWA County 16 POWESHIEK (or town) 7:9

Latitude: 414430 N Longitude: 0924330 Sequential number: 1

Lat-long accuracy: 3 T 80 S, R 16 Sec 16, SW NW 5

Local well number: 08016W163C Other number: W-6931

Local use: 06931 SOCIETY 7 Owner of name: GRINNELL CITY WELL #7

Owner or name: GRINNELL IOWA Address: GRINNELL, IA.

Ownership: County, Fed Gov't, (M) City, Corp or Co, Private, State Agency, Water Dist M

Use of water: (A) Air cond, Bottling, Comm, Dewater, Power, Fire, Dom, Irr, Mad, Ind, P S, Rec, (S) Stock, Instit, Unused, Repressure, Recharge, Desal-P S, Desal-other, Other P

Use of well: (A) Anode, Drain, Seismic, Heat Res, Obs, Oil-gas, Recharge, Test, Unused, Withdraw, Waste, Destroyed. (W)

DATA AVAILABLE: Well data 3 Freq. W/L meas.: INVENTORY 0 Field aquifer char. 72

Hyd. lab. data: 73

Qual. water data: type: COMPLETE 74 C

Freq. sampling: INTERMITTENT (8/30/55) I Pumpage inventory: yes 76 no: period: 77

Aperture cards: 78

Log data: GEOLOGIST LOG 79 G

#### WELL-DESCRIPTION CARD

SAME AS ON MASTER CARD Depth well: 2550 ft 2550 Meas. Drillers Log 24 3

Depth cased; (first perf.): 2190 ft 2190 Casing type: STEEL; Diam. 19 in 19

Finish: porous concrete, gravel w. (perf.), (G) gravel w. (screen), (H) horiz. gallery, (O) open end, (P) peff., (S) screen, (T) sd. pt., (W) shored, (X) open hole, (B) other P

Method: (A) air bored, (B) cable, (C) dug, (D) hyd, (H) jetted, (J) air, (P) reverse, (R) trenching, (T) driven, (V) drive wash, (W) percussive, (X) rotary, (B) other C

Date Drilled: OCT 1955 955 Pump intake setting: 30 ft 30

Driller: THORPE WELL CO. DES MOINES, IA.

Lift (type): (A) air, (B) bucket, (C) cent, (J) jet, (L) multiple, (M) multiple, (N) none, (P) piston, (R) rot, (S) submerg, (T) turb, (B) other S Deep D Shallow 40

Power (type): diesel, (elec) nat gas, gasoline, hand, gas, wind; H.P. 5 Trans. or meter no. 41

Descrip. MP LSD ft above LSD, Alt. MP 1011

Alt. LSD: 1011 Accuracy: ALTIMETER 47 7

Water Level: 298 ft above MP; Ft below LSD 298 Accuracy: DRILLER'S LOG 52 D

Date meag: JAN. 1960 160 Yield: 875 gpm 875 Method determined 61

Drawdown: 174 ft 174 Accuracy: 3 Pumping period 46 hrs 68

QUALITY OF WATER DATA: Iron 0.58 Sulfate 4 Chloride 21 Hard. 362 7

Sp. Conduct 990 K x 10<sup>6</sup> 8 Temp. 75 F 75 Date sampled 1/22/60 160

Taste, color, etc. 48

Well No. 080-16W-163C

Punched ERC

Verified FCH

Well No. 080-16W-16BC

Latitude-longitude 41 44 30 <sup>N</sup> 092 43 30 <sup>W</sup>

HYDROGEOLOGIC CARD

SAME AS ON MASTER CARD 1:2 Physiographic Province: CENTRAL LOWLAND Section: DISSECTED

Till Plain E Drainage Basin: IOWA 2:5:D Subbasin: \_\_\_\_\_

Topo of well site: (D) depression, stream channel, dunes, flat, hilltop, sink, swamp, (E) offshore, pediment, hillside, terrace, undulating, valley flat FLAT F

MAJOR AQUIFER: CAMBRIAN, UPPER C3 JORDAN SS. SJ  
 system series aquifer, formation, group

Lithology: COARSE SANDSTONE 4:V Origin: MARINE 6 Aquifer Thickness: 54 ft

54 Length of well open to: 54 ft 54 Depth to top of: 2192 ft B19

MINOR AQUIFER: CAMBRIAN, UPPER C3 ST. LAWRENCE S5  
 system series aquifer, formation, group

Lithology: FINE DOLOMITE 2:D Origin: MARINE 6 Aquifer Thickness: 262 ft

262 Length of well open to: 262 ft 262 Depth to top of: 2246 ft B25

Intervals Screened: NONE

Depth to consolidated rock: 233 ft 233 Source of data: WELL CUTTINGS C

Depth to basement: 2955 ft 2955 Source of data: DRILLER'S LOG D

Surficial material: \_\_\_\_\_ Infiltration characteristics: POOR 4


Coefficient Trans: \_\_\_\_\_ gpd/ft \_\_\_\_\_ Coefficient Storage: \_\_\_\_\_

Coefficient Perm: \_\_\_\_\_ gpd/ft<sup>2</sup>; Spec cap: \_\_\_\_\_ gpm/ft; Number of geologic cards: \_\_\_\_\_

CASING:

700' OF 19" CASING (CEMENTED) 0-700 FT  
 1325' OF 12" LINER (CEMENTED) 675'-2000 FT  
 710' OF 10" LINER 1975'-2685'


WELL WAS 2970 FT DEEP - PLUGGED  
 BACK TO 2550 FT.



SWL @ 825' DEPTH WAS 425 FT  
 SWL @ 880' DEPTH WAS 370 FT  
 SWL @ 950' DEPTH WAS 429 FT.  
 SWL @ 2970' DEPTH WAS 304.7 FT.

Well No.


080-16W-16BC




GEN. DATA


IOWA GEOLOGICAL SURVEY In Cooperation with U. S. GEOLOGICAL SURVEY Iowa City, Iowa		
Name <i>Grinnell City Well #7</i>		State <i>Iowa</i>
Town <i>Grinnell</i>	County <i>Poweshiek</i>	Loc. <i>SW NW</i>
Contractor Driller <i>Thorpe Well Co.</i>		Sec. <i>16</i>
Drilling Dates <i>Sept. 1954 - Nov. 1955</i>		T. <i>80 N., R. 16 W.</i>
Casing Record		
<i>700' of 19" casing 0-700' (cemented in)</i>		
<i>1325' of 12" liner 675-2000' (cemented in)</i>		
<i>710' of 10" liner 1975-2685'</i>		
<i>well plugged back to 2550' and perforated opposite Jordan and St. Lawrence</i>		
S.W.L.	G.P.M.	D.D.
Remarks		Elev. <i>1011'</i>
		T.D. <i>2970'</i>
Logged By <i>Northrup Dec. 1954 - Nov. 1955</i>		I.G.S. No. <i>W-6931</i>


- Explanation of Colors
- Soil
  - Loess, Silt on Siltstone
  - Drift
  - Sand & Gravel
  - Shale
  - Sandstone
  - Limestone
  - Dolomite
  - Chert
  - Gypsum or Anhydrite
  - 
  - No Samples



















SEP 8 1955



**GRINNELL'S NEW DEEP WELL** is nearing completion with indications that it will meet the city's water needs for generations to come. Drilling has been finished to the contract depth of 2700 feet with a 12-inch hole. Output in test pumping (shown above) has reached 925 gallons per minute. The city has decided to drill down from 75 to 150 feet deeper with the aim of further production and less draw-down by reaching a new vein. Putting a 10-inch hole on down will not damage the well and is expected to increase capacity. Thorpe Well Co. of Des Moines is the contractor.

IOWA PRESS  
CLIPPING BUREAU

Des Moines, Iowa

Herald Register  
Grinnell, Iowa

OCT 22 1953

## Council To Investigate New Deep Well Here; Consider No. 5 Well Conversion

Tom and Phil Thorpe, representatives of Thorpe Well Company, Des Moines, strongly urged council members to convert the city's No. 5 well from an oil lubricated shaft to a water lubricated shaft.

Repair and maintenance, both from the cost and time angles, were given as the reason for the suggestion by the well men.

### Cite Sales, Service

The Thorpes cited sales of 100 "water" lubricated units for every "oil" lubricated pump sold. Since spare parts are stocked in similar ratios, there is often a long waiting period for repair parts for "oil" lubricated shafts, as evidenced by the long wait here in conjunction with the No. 5 well repair this summer.

Estimated cost of converting the No. 5 well, including an extension of 20 feet to get further down into the well supply, was

placed at \$5000. Use of stainless steel shafting would up the cost by \$1800, although this move was recommended by the Thorpes.

### Lose Oil

Another point mentioned by the well company representatives was that "oil" lubricated pumps often lose their oil, which drops down into the well. This process could get into the filtering sand, causing heavy costs for sand replacement.

Councilmen decided to hold a special meeting the latter part of this week to take action on the conversion proposal.

Councilmen moved unanimously to initiate investigating action with regard to securing a new city water well.

The motion approved by the council was to have city engineer, Don Ferguson and George Clifton, head of the water committee, draw up plans and specifications for a new deep well.

George Clifton, mayor pro-tem, presided at the meeting in the absence of Mayor Tom Godfrey.

### Estimated Cost

Tom and Phil Thorpe of the Thorpe Well Company, Des Moines, estimated the cost of the new well and pump at approximately \$100,000. They said that the new well would produce from 800 to 1000 gallons per minute and would require about one year to complete.

In discussions on the new well, the Thorpes stated that the static water level in the city's present wells has dropped some 23 feet since 1941, in a steady drop of some two feet per year.

Financing the well construction would probably be thru the issuance of revenue bonds and paid from earnings of the water department.

### Approval

It was pointed out that the state board of health must give their okay to both plans and proposed sites.

The Thorpes told of well drilling jobs held by the company and cited several possible types of wells to be drilled.

SEP 8 1955

group.

## Continued Drilling Is Authorized

### City Expects To Go Additional 150 Feet To Hit New Water Level

Thorpe Well Company has been authorized to renew drilling at the Grinnell No. 7 well at least through the Dolemite strata, when the issue will again be reviewed by city officials.

By all indications, the city will authorize drilling up to 150 feet on the supposition that a much larger water vein will be hit in that distance.

#### 10-Inch Hole

Mayor Tom Godfrey said that drilling will resume with a 10-inch hole to be drilled through the present strata. If necessary additional soils tests will be taken to determine whether deeper drilling will be beneficial.

An earlier test indicated that Grinnell could hit a large water strata within another 75 to 150 feet. Water at that level, the report said, should be abundant and much softer than that hit at the 2500 foot level.

#### Supply Sufficient

Even so, the present supply is sufficient and meets requirements expected of the new well. Tests produced more than 1,000 gallons per minute from the new well.

But while the new well is producing 1000 gallons a minute, water Superintendent Bernie Matherly has noticed a slight drop in production from other city wells connected to the same vein.

Drillers ran into some trouble this past week when a unit became lodged in the 12-inch pipe, but have been successful in removing the piece of equipment.

*P. W. ...*

November 24, 1953

Mr. C. W. Durham  
Henningson, Durham & Richardson, Inc.  
2962 Harney Street  
Omaha 2, Nebraska

Dear Mr. Durham:

We are replying to your letter of November 17 requesting information on the city water supply at Grinnell, Iowa, and pertinent comments relative to the construction of an additional deep well. The available data from the files of the cooperative investigations of the Iowa and U. S. Geological Surveys are summarized as follows:

The Grinnell city water supply is derived from two deep wells No. 5 and No. 6, 2260 and 2498 feet deep respectively, located at the city water pumping station at Second and Main Streets. Wells 1, 2, 3, and 4 have all been abandoned. Well 4, a 2000-foot hole, was plugged up about three years ago to decrease the possibility of contamination of the deep aquifers. The following geologic section was encountered in the drilling of Well 6. All depth figures are referred to the altitude of the well curb 1020 feet above sea level.

<u>Formation and description</u>	<u>Thickness (ft.)</u>	<u>Depth (ft.)</u>	
		<u>From</u>	<u>To</u>
<b>Pleistocene</b>			
No samples (pebbly clay with sand at base)	200	0	200
<b>Mississippian system</b>			
St. Louis limestone (sandy limestone)	30	200	230
Keokuk formation (cherty dolomite)	68	230	298
Burlington limestone	42	298	340
Hampton formation (cherty dolomite and limestone)	50	340	390
English River siltstone	30	390	420
Maple Mill shale	130	420	550

**Devonian system****Lime Creek formation**

Shaly dolomite	40	550	590
Shale	90	590	680

**Cedar Valley formation**

Limestone	80	680	760
Dolomite with gypsum	170	760	930
Dolomite	50	930	980

**Wapsipinicon formation**

Dolomite and gypsum	50	980	1030
Cherty limestone	120	1030	1150

**Silurian system**

Undifferentiated cherty dolomite	40	1150	1190
----------------------------------	----	------	------

**Ordovician system**

Maquoketa shale (shale with dolomite in lower part)	240	1190	1430
Galena dolomite (cherty in lower part)	190	1430	1620
Decorah-Platteville formations (shale and limestone)	80	1620	1700
St. Peter sandstone	30	1700	1730
Prairie du Chien formation (dolomite with sand zone 1870-1970 feet)	460	1730	2190

**Cambrian system:**

Jordan sandstone	60	2190	2250
St. Lawrence dolomite	100	2250	2350
Franconia formation (siltstone and silty dolomite)		2350	2500 T. D.

The casing records of these wells indicate that City Well 5 is cased from surface into the top of the Prairie du Chien formation, whereas, in Well 6 the St. Peter sandstone is left uncased. The Jordan sandstone is the main aquifer in these wells. Well 6 has been tested at 650 and 375 gallons a minute with drawdowns of 90 and 35 feet respectively, and Well 5 at 357 gallons a minute with a drawdown of 46 feet. These tests, however, probably represent only short periods of pumping. The water level in the deep city wells was initially about 250 feet below the surface, but was 270 feet below in 1942 indicating that the constant pumping of these wells has reduced the local pressure head of the Jordan aquifer. To prevent excessive interference a new deep well should be located a considerable distance from Wells 5 and 6.



Mr. C. W. Durham

3

November 24, 1953

Mineral analyses of water samples from City Wells 5 and 6 are given on a separate sheet. Note that Well 5 seems to be less mineralized than Well 6. The reason for the increase in mineralization in Well 6 for the sample collected in 1952 is not known, but it may represent a mixture of shallow and deep waters.

The shallower aquifers in this general area contain rather highly mineralized waters. Therefore, a new deep well at Grinnell should be cased at least as far as the top of the St. Peter sandstone and seemingly the quality would be improved by casing a considerable distance into the Prairie du Chien dolomite or as far as the top of the Jordan sandstone.

We hope this report will assist you in your work. If we can supply further data in this regard, please let me know.

Very truly yours,

H. G. Hershey

HGH:PJH:t  
Enclosure

*Not advised  
during drilling  
of well No. 8*

IOWA GEOLOGICAL SURVEY  
 TABULATION OF WATER ANALYSES  
 (Dissolved constituents in parts per million)

COUNTY \_\_\_\_\_

TOWN - Well No. Use - Location	Date of coll.	Depth (ft.)	Geol. source	°F.	Diss. solids	Fe	Mn	Ca	Mg	K/Na Na+ K(as Na)	HCO <sub>3</sub>	SO <sub>4</sub>	Cl	F	NO <sub>3</sub>	Hardness (calc. as CaCO <sub>3</sub> )			pH	Cond.	
																Tot.	Carb.	Non-carb.			
Grinnell City Well No. 5	6/16/34	2006	Jordan Pr. du ch.		794	2	.0	74	39	117	356	277	22	1.0	.89	345	292	53	7.7		
" "	8/30/40	"	"	71	714	.3	.0	84	37	89	359	261	19	1.9	.0	362	294	68	7.7		
" "	6/16/42	"	"	75	774	.4	.0	133	40	32	356	256	17	1.0	.4	497	292	205	7.3		
" "	8/20/52	"	"		787	.2	0	100	39	21/110	347	325	22	1.6	.62	410	284	126	6.9		
Grinnell City Well No. 6	9/27/34	2498	"		908	1.4	.06	92	42	137	354	365	24	1.5	.0	404	290	114	7.5		
" "	3/13/37	"	"	74	814	1.2	.02	107	34	117	344	328	26	1.0	1.3	407	282	125	7.4		
" "	8/30/40	"	"	75	829	.3	.0	92	36	122	356	344	25	2	.0	378	292	86	7.2		
" "	8/20/52	"	"		1659	1.0	0	171	50	23/269	322	892	55	1.6	0	633	264	369	6.9		

NOTES:



NOV 18 1953

REGISTERED ENGINEERS

C. W. DURHAM  
W. A. RICHARDSON  
W. L. BREDAR  
W. S. HANSEN  
V. L. HILL  
J. Z. JIZBA  
A. E. LAWSON  
E. F. MANGIAMELI  
F. J. MATTHIES  
G. E. MILLER  
R. L. REINS  
V. V. SEARS  
D. R. STUART  
F. A. TOWL  
W. R. WARNE  
.....

TELEPHONE JACKSON 2164

# HENNINGSON, DURHAM & RICHARDSON, INC.

## CONSULTING ENGINEERS FORMERLY HENNINGSON ENGINEERING CO.

2962 HARNEY STREET  
OMAHA 2, NEBR.

November 17, 1953

ASSISTANT ENGINEERS

B. F. BANDUR  
W. H. CAVNER  
B. J. CHRISTENSEN  
B. E. DANIELS  
G. R. EICHENBERGER  
J. J. FORMAN  
P. R. OMBRUNI  
B. H. PLOWGIAN  
R. A. ROHLING  
D. G. SCHOLER  
R. V. SOUTHWORTH  
W. V. TIETSORT  
J. T. TAMAI  
J. T. WHITESIDE, JR.  
K. H. WICKERSHAM  
.....

J. J. FORMAN, ATTY.

Dr. H. G. Hershey  
State Geologist  
Iowa City, Iowa

Re: Water Supply - Grinnell, Iowa

Dear Dr. Hershey:

Our firm has been requested by the Grinnell City Council to assemble some preliminary information relative to the construction of another deep well.

We would appreciate it if you would send us information which you have relative to the Grinnell water supply and any thoughts you might have in connection with this matter.

We would appreciate your prompt attention to this matter inasmuch as we have promised them an early report.

Very truly yours,

HENNINGSON, DURHAM & RICHARDSON

CWDurham/ER

By *C. W. Durham*

IOWA PRESS  
CLIPPING BUREAU

Des Moines, Iowa

Herald Register  
Grinnell, Iowa

JAN 18 1954

## Council Eyes Water Rate Change To Finance Deep Well Construction

Possible revamping of the city water department financial structure to make way for construction of a new deep well was given preliminary consideration at Monday night's city council meeting.

Figures in the annual municipal financial report disclosed that the department under the present rates is not making sufficient profit to finance revenue bonds and interest for the well project.

### Increase Offset

Continuing increases in costs of upkeep materials were cited as more than offsetting additional revenue gained from the last re-adjustment in water rates. Another change in fees may be in the offing.

Mayor Tom Godfrey requested Councilman George Clifton, chairman of the water committee, to confer with City Engineer Don Ferguson and Bernie Matherly, water superintendent, and prepare specific recommendations for presentation at the next council session.

IOWA PRESS  
CLIPPING BUREAU

Des Moines, Iowa

Herald Register  
Grinnell, Iowa

MAY 13 1954

## Bids Sought For Drilling Deep Well

To Be Opened June 14;  
Specifications Call  
For Depth of 2700 Ft.

Bids for drilling of the new deep well will be opened June 14 at 7:30 p. m., according to action taken at a special meeting of the Grinnell city council Monday night.

Specifications call for a well 2700 feet deep to be located at the northeast corner of the old reservoir site on West street between First and Second avenues. Work is to be started within 20 days after the contract is let and the project is to be completed by Dec. 31, 1955.

### Diameters Given

According to City Engineer Don Ferguson, who prepared the plans and "specs", the well will have a 26-inch diameter opening at the top, a 12-inch diameter from 700 to 2000 feet in depth and a 10 to 12-inch hole to the bottom.

The legal notice on the well, appearing elsewhere in this issue, outlines the work to be done and gives all requirements.

Councilmen also entered into a contract with the Carleton D. Ben Co. of Des Moines for financing and bond service in connection with the proposed waterworks improvement (deep well).

### Other City Business

Ferguson was directed by the council to draw up a contract with the Robison Brothers for demolishing and leveling the old concrete reservoir. The Robison bid was for \$975.

A new half-ton Ford pickup was purchased from Pulis-Johnson Motor Co. for the sewage disposal department. The Ford bid was \$1095 plus the old truck. Four other Grinnell automotive agencies submitted bids.



Harald Register  
Grinnell, Iowa

MAY 17 1954

## COUNCIL PROCEEDINGS

### NOTICE TO BIDDERS

Notice of Public Hearing on Proposed Plans and Specifications and proposed Form of Contract for the construction of Improvements and Extensions to the Municipal Waterworks of the City of Grinnell, Iowa, and of taking of bids for such improvements and extensions.

Notice is Hereby Given that the City Council of the City of Grinnell, Poweshiek County, Iowa, will meet at the City Hall, in the Council Chamber, Grinnell, Iowa, on the 14 day of June, 1954, at 7:30 o'clock P. M., at which time and place or at such later time and place as the Council may then fix, said Council proposes to adopt plans and specifications and form of contract and to receive bids for the construction of improvements and extensions to the municipal waterworks of said City and to enter into a contract for the construction of said improvements and extensions. Said proposed improvements and extensions are in general as follows:

Section A. Drilled Well. Construct a deep well, drilled, approximately twenty-seven hundred (2,700) feet in depth including necessary drilling, casing, cement grouting, developing and testing.

Section B. Deep Well Turbine Pump. Furnish and install a deep well turbine pump including the necessary electrical and control equipment.

Section C. Electrical and Watermain Connections. Make necessary electrical and watermain connections.

All work, material and equipment is to be in accordance with the plans and specifications and proposed form of contract now on file in the office of the City Clerk of Grinnell, Iowa, by this reference made a part hereof as though fully set out and incorporated herein. Bids must include payment by the contractor of any use or sales tax upon the materials furnished.

At the said time and place said Council will also consider bids for the furnishing of water for the use of said City and it is estimated that the needs of the City will require approximately 250,000,000 gallons per year.

All proposals and bids in connection therewith shall be submitted to the City Clerk of said City on or before the time herein set for said hearing. All proposals shall be made on official bidding blanks furnished by the City and any alterations in the official form of proposal will entitle the Council, at its option, to reject the proposals involved from consideration. Each proposal shall be sealed and plainly identified.

Each proposal shall be accompanied in a separate envelope by a certified check in an amount equal to ten per cent (10%) of the total amount of the bid, drawn on and certified to by a bank in Iowa, payable to the Treasurer of the City of Grinnell, Iowa, as security that if awarded the contract by resolution of the City Council, the bidder will enter into a contract at the prices bid and will furnish the required corporate surety bond. This certified check may be cashed and the proceeds retained by the City of Grinnell, Iowa, as agreed liquidated damages if the bidder fails to execute a contract or file an acceptable bond for the faithful performance thereof, within ten (10) days after the acceptance of his proposal by resolution of the City Council.

At said hearing the City Council will consider the plans and specifications and proposed form of contract for the project, the same now being on file in the office of the city Clerk, reference to which is made for a more detailed and complete description of the proposed improvements, and at said time and place the said Council will also receive and consider any objections to said plans, specifications and form of contract made by any interested party.

Payment for said improvements and extensions will be made in cash or in revenue obligations which said revenue obligations will be payable solely and only out of the net earnings of said municipal waterworks. The City shall not incur any general obligations for said improvements and neither the contract for the construction of said improvements and extensions nor said revenue obligations shall constitute a general obligation of the City or be payable in any manner by taxation and under no circumstances shall the City be in any manner liable by reason of the failure of said net earnings to be sufficient for the payment of said revenue obligations and the interest thereon.

Payment to the contractor will be based on monthly estimates equivalent to eighty-five per cent (85%) of the contract value of the work completed during the preceding calendar month. Estimates will be prepared on the first day of each month by the contractor, subject to the approval of the Engineer, who will certify to the City for payment, each approved estimate on or before the tenth (10th) day of the month in question. Final payment of the remaining fifteen per cent (15%) will be made thirty (30) days after completion and acceptance by resolution of the City Council of the completed contract, assuming that no unpaid claims then remain on file in accordance with the provisions and conditions of Chapter 573 of the Code of Iowa, 1950, as amended. No such partial or final payment will be due until the Contractor has certified to the City Clerk that the materials, labor and service, involved in each estimate have been paid for in accordance with the requirements stated in the specifications.

The successful bidder shall furnish a performance bond in an amount equal to 100% of the contract price, which bond shall also guarantee the completed work against defects of workmanship or materials for a period of one (1) year from and after completion and acceptance by the City Council.

The work shall be commenced within 20 days after the award of contract and shall be completed on or before the 31 day of Dec. 1955, subject to any extensions of time which may be granted by the City Council.

The City reserves the right to award contract at the time of said meeting or at such later time as may then be fixed and to reject any or all bids, and to enter into such contract or contracts if shall deem to be for the best interest of said City.

These improvements are being constructed pursuant to authority granted the municipality under the provisions of Chapter 337 of the Code of Iowa, 1950. By virtue of statutory authority preference will be given to products and provisions grown and coal produced within the State of Iowa, and to Iowa domestic labor.

Proposed plans and specifications and form of contract are now on file in the office of the City Clerk of Grinnell, Iowa. Copies may be obtained from D. W. Ferguson, City Engineer, of Grinnell, Iowa, upon a deposit of \$25.00 for one set, all of which will be refunded to bona fide bidders who bid in their own name provided plans and specifications are returned in good condition within fifteen days after the award of contract. The full amount of the deposit will be returned to all other parties provided plans and specifications are returned in good condition within five days after date of hearing. No refund will be made for plans and specifications not returned within these periods. Additional sets or partial sets of plans and specifications will be furnished by the Engineer when requested at cost of reproduction which will not be refunded.

This Notice is given by order of the Council of the City of Grinnell, Iowa.

Sam Godfrey Mayor

Attest: Elmer B. Lowrey

City Clerk

May 13-20

Grinnell (Poweshiek)

Section A. Drilled Well. Construct a deep well, drilled, approximately twenty-seven hundred (2,700) feet in depth including necessary drilling, casing, cement grouting, developing and testing.

Section B. Deep Well Turbine Pump. Furnish and install a deep well turbine pump including the necessary electrical and control equipment.

Section C. Electrical and Watermain Connections. Make necessary electrical and watermain connections.

All work, material and equipment is to be in accordance with the plans and specifications and proposed form of contract now on file in the office of the City Clerk of Grinnell, Iowa, by this reference made a part hereof as though fully set out and incorporated herein. Bids must include payment by the contractor of any use or sales tax upon the materials furnished.

At the said time and place said Council will also consider bids for the furnishing of water for the use of said City and it is estimated that the needs of the City will require approximately 250,000,000 gallons per year.

All proposals and bids in connection therewith shall be submitted to the City Clerk of said City on or before the time herein set for said hearing. All proposals shall be made on official bidding blanks furnished by the City and any alterations in the official form of proposal will entitle the Council, at its option, to reject the proposals involved from consideration. Each proposal shall be sealed and plainly identified.

Each proposal shall be accompanied in a separate envelope by a certified check in an amount equal to ten per cent (10%) of the total amount of the bid, drawn on and certified to by a bank in Iowa, payable to the Treasurer of the City of Grinnell, Iowa, as security that if awarded the contract by resolution of the City Council, the bidder will enter into a contract at the prices bid and will furnish the required corporate surety bond. This certified check may be cashed and the proceeds retained by the City of Grinnell, Iowa, as agreed liquidated damages if the bidder fails to execute a contract or file an acceptable bond for the faithful performance thereof within ten (10) days after the acceptance of his proposal by resolution of the City Council.

At said hearing the City Council will consider the plans and specifications and proposed form of contract for the project, the same now being on file in the office of the city Clerk, reference to which is made for a more detailed and complete description of the proposed improvements, and at said time and place the said Council will also receive and consider any objections to said plans, specifications and form of contract made by any interested party.

# City Council to Decide on 'Liner' For No. 5 Well at Meeting Tonight

6/14/54

Grinnell  
(Pawshick)

Contracts for Grinnell's new 2,700-foot No. 7 well will be let at the meeting of the city council tonight (Monday), and a decision is expected at the same meeting concerning the future of the "on-again-off-again" No. 5 well.

Trouble with the city's 2,260-foot No. 5 well started some weeks ago when production slacked off from a normal output of 820 gallons a minute to about 200 gallons within the space of 24 hours.

### Output Drops

"Balling out" of the well at that time restored the output to near normal, but the water yield dropped again sharply last week to about half of normal.

It was then that the city council voted to conduct an extensive test of the well to determine what if anything was wrong with it, and what if anything could be done to restore the water yield permanently to its normal flow.

Consequently, the Schlumberger Well Surveying company of Houston, Texas, was contacted and sent a crew of specialists to Grinnell to examine the faulty well Friday.

### Engineer Reports

At a council meeting Friday evening, Bill Beazley, the electrical engineer in charge of the testing crew, gave the council the following report:

The crew ran three separate tests on the well. First test consisted of a continuous record of temperature changes of the water in the well by lowering a "thermometer" to the bottom.

Second check consisted of an "electrical log" of the various strata of rock through which the well passed. This was accomplished by means of a device which sent out electrical impulses, and recording the amount of resistance encountered as the instrument gradually was lowered to the bottom. Generally speaking, high resistance indicates solid material, while low resistance would show softer strata.

### Record Width

Thirdly, the crew lowered a "calibration" instrument which recorded the exact width of the well from top to bottom.

Results of the tests, which cost \$981.28, showed conclusively that the metal lining of the well, which reaches down to the 1,741-foot level, is not broken or cracked, and that the "open" hole below the metal lining has not been seriously clogged.



**A LONG WAY DOWN**—A technician for the Schlumberger Well Surveying company guides an electronic instrument on the first few feet of its 2,260-foot journey down to the bottom of Grinnell's No. 5 well. The instrument determined the type of rock through which the well was drilled.

### No Obstruction

It is possible, according to the engineer, that a minor obstruction might have been removed by the lowering of the instruments without being recorded, but no major obstructions were encountered.

At Monday's meeting, the council will decide whether or not to install a further metal liner all the way to the bottom of the well.

Since this part of the liner would go through the water-bearing strata, it would have to be perforated to permit water to enter the well. However, it would probably prevent any further clogging of the well.



Grinnell (Powershiek)

Herald Register  
Grinnell, Iowa

JUN 17 1954

# Contract Let, Work to Be Started Soon

To Be 2700 Feet Deep;  
Financed Solely with  
Revenue Bonds

Thorpe Well company of Des Moines was awarded the contract for drilling Grinnell's new deep well at a special meeting of the city council Monday night.

Low bid submitted by the Thorpe Co. was for \$113,686 but the cost may vary somewhat from that figure depending on what size pump is installed and other alternates in construction which will be decided as work progresses.

Rayne Western of Ames, another leading well-drilling firm, also submitted a complete bid for \$118,234 or \$4,548 more than the Thorpe estimate. Varner Well and Pump Co. of Dubuque submitted bids on the pump and water main hookup but not on the drilling.

### Within Three Weeks

Work on the new well, first to be drilled here since 1926, will begin within three weeks. Completion date is Dec. 31, 1955.

Financing of the project will be by revenue bonds handled by the Carleton D. Beh Co. of Des Moines under extension of a previous contract on waterworks improvements including the reservoir.

Revenue bonds can be paid off only by future net earnings of the waterworks and there can be no tax levy against property to liquidate the bonds, even in case of default.

Plans for the new well, to be located on the north side of the old reservoir site (Second avenue and West street), call for a depth of 2700 feet below the surface.

### Dimensions

A 20-inch steel pipe casing will be installed to a depth of 675 feet to be followed by a 12-inch steel pipe casing to a depth of 2000 feet. A 12-inch diameter uncased hole will be drilled the remaining 700 feet to the bottom of the well.

There is to be cement grouting in the space back of the casings to a depth of 2000 feet.

IOWA PRESS  
CLIPPING BUREAU

Des Moines, Iowa

Herald-Register  
Grinnell, Iowa

JUL 8 1954

# Expect Deep Well Work to Start Soon

Work on drilling of Grinnell's new deep well is expected to start in the near future.

Men from the Thorpe Well Co. of Des Moines, contractor for the job, are expected here later this week to inspect the site preparatory to setting up the drilling rig. The Thorpe company was delayed in its operations elsewhere by the recent floods.



Herald-Register  
Grinnell, Iowa  
SEP 6 1955

# Start Drilling On New 2,700-Foot City Well

## Police Report Minor Area Accidents Over Labor Day Weekend

Police reported two minor area accidents over the Labor Day weekend.

An accident occurred at the Rock Island crossing on the old detour about 3 1/2 miles east of town Monday evening at 5 o'clock. Earl Warren Carmer of Grinnell, rolled his 1937 Chevrolet at the crossing.

Highway patrolman Gerald Kahler, the investigating officer, filed charges against Carmer for operating a vehicle without a driver's license.

### Sunday Morning Mishap

Police also reported memorandum information on an accident that occurred about 7 a. m. Sunday on the Highway 6 detour east of town. James Butdy Daniels of Omaha left the road in his 1952 Mercury sports coupe.

Daniels car rolled 1 1/2 times according to reports. Damages to the car were estimated at \$450. The driver was unhurt.



**CIVIC MILESTONE** — Councilman George Clifton, chairman of the water committee, shovels the first dirt Friday in ground-breaking for the city's new deep well as other council members and the mayor await their turns. In the group, left to right: Bernie Matherly, waterworks superintendent; Councilman Bob Breiting; Don Kunkel, driller for Thorpe Well Co.; Clifton; City Engineer Don Ferguson; Councilmen Howard Sage, Carl Speth, John Hotchkin and Ed Speth; and Mayor Tom Godfrey.

## Target Date For Operation Is Dec. 31, '55

### Thorpe Well Company Starts Work on Site of Former City Reservoir

Drilling started late last week on Grinnell's first new deep well in nearly 30 years.

Located on the site of the old reservoir on West street, "Number Seven" is scheduled to be in operation by Dec. 31, 1955, according to Don Ferguson, city engineer.

Mayor Tom Godfrey and members of the city council participated in the ground-breaking ceremonies Friday morning which formally launched beginning of work on the 2,700-foot shaft by the Thorpe Well company of Des Moines.

City officials hope for an output of at least 800 gallons a minute, and possibly as high as 1,000 gallons, once the new well goes into operation. The city's No. 5 and 6 wells are now producing about 1,400 gallons a minute between them.

Cost of the entire operation, including drilling, pump and connections, will come to about \$14,000, Ferguson said. The well will be financed by sale of revenue bonds.

Poweshie

June 18, 1954

Thorpe Well Company  
2340 Sixth Avenue  
Des Moines, Iowa

Attention Mr. Phil Thorpe

Gentlemen:

We are glad to supply the following information in regard to the possibilities of obtaining a ground-water supply of 35-40 gpm from a well drilled to a depth of approximately 300 feet at a site in the City of Grinnell. All data were obtained from the files of the Iowa and U. S. Geological Surveys.

Glacial Drift is expected to be approximately 200 to 225 feet thick at this site, underlain by rocks of Mississippian age. In Grinnell City Well No. 5, 181 feet of Mississippian limestone was encountered from 209 to 390 feet.

Records of wells in and around Grinnell indicate that a layer of sand up to 15 feet in thickness occurs at the base of the unconsolidated materials and that this sand layer contains rather large quantities of water. However, this sand in most cases is quite fine and commonly difficult to exclude from a well without decreasing the water yield.

If a well cannot be developed satisfactorily in the sand at the base of the Glacial Drift, there is some possibility that the desired amount of water can be obtained by deeper drilling into the consolidated rocks. The Mississippian rocks in this area are not known to yield large quantities of water to wells. However, records of farm wells in the area indicate yields of from 5 to 30 gpm have been obtained from wells drilled into or through the limestones of Mississippian age.

To summarize: It is believed that rather large quantities of water are present in a layer of fine sand at the base of the Glacial Drift. It may or may not be possible to satisfactorily construct a well in this sand layer. A well drilled into the consolidated rocks could be expected to

**Thorpe Well Company**

**2**

**June 18, 1954**

**yield moderate quantities of water. There is some possibility that the desired amount could be obtained from these rocks.**

**If this office can provide you any further information, please do not hesitate to call on us.**

**Very truly yours,**

**H. G. Hershey  
By J. B. Cooper**

**HGH:JBC:t**



Grinnell (Powershick)

**IOWA PRESS  
CLIPPING BUREAU**

Des Moines, Iowa

**Herald-Register  
Grinnell, Iowa**

JAN 3 1955

## New Well May Have Pump Under Ground

Administrators Will  
Tour Plant And View  
Units in Operation

A submerged pump may be used in operation of the new city water well at Grinnell.

Mayor Tom Godfrey, impressed with preliminary sketches of the submerged pump, said today that he along with City Clerk Homer Lowrey and two or three city councilmen expect to inspect operation of similar installations within the next week or two.

### Down 1265 Feet

The new city well had reached 1,265 feet prior to the new year and the time is drawing close for officials to make a decision if the submerged pumps are to be used.

The city administrators will be guests of the company on January 16 when they will tour the Freeport, Ill., plant where the pumps are made. They will also tour several communities where the pumps are in operation, Godfrey said.

### See Before Deciding

Though impressed with the submerged set up, Godfrey explained that he and councilmen would have to see the pumps in operation before making a decision.

Said to be more economical, the submerged pump is located at the bottom of the well shaft and instead of pulling water up, would push it from below. Godfrey said the main economical feature is elimination of big and expensive well pipes.

**IOWA PRESS  
CLIPPING BUREAU**

Des Moines, Iowa

**Herald-Register  
Grinnell, Iowa**

DEC 9 1954

## Water Well Is Ahead of Schedule Council Advised

Grinnell's new water well may be in operation well in advance of the anticipated completion date, according to a progress report presented to the city council Monday night.

Water chairman George Clifton reported that steel casings have been put in and that the well is down to 705 feet. Thorpe Well Drilling official said they expect to reach 1,000 feet by the first of the year and will be "all through" by May 1.

The officials told Mayor Tom Godfrey that "you'll be drinking water from this well by May 1."

~~Jasper~~  
Poweshoke

MEMORANDUM

December 14, 1954

To: H. G. Hershey  
From: R. Gale McMurtrey  
Subject: Well at Grinnell

On the return trip from checking the water levels and water-level recorders at Rock Creek (Jasper county), I stopped at Grinnell to check on the progress of the well being drilled for the town by Thorpe Well Company.

Twenty-inch casing with  $\frac{1}{2}$ " wall was cemented in from 0-700 feet the 7th of December. The Haliburton method was used to cement the casing in, and 944 sacks of cement were used in the process.

As of today (12/14/54) at 11:00 a.m. the hole was down to 950 feet. A 19" bit has been used from 700' to the present depth.

At 825' the w/l was 425'; at 880 feet the the w/l was 370'; and the present w/l is back down to 429'.

Samples from 182' to 900' were picked up. Samples from 0-182' are on the rotary drill rig which was used in the upper material.

Gale



*Grinnell Register*

IOWA PRESS  
CLIPPING BUREAU  
Des Moines, Iowa

Herald-Register  
Grinnell, Iowa

JUL 25 1955

# Use 604,000 Gallons Of Water Daily

## Grinnell Daily Water Consumption Up 3,000 Gallons Over Last July

The recent heat wave has seen city water consumption figures rise steadily during the past several days according to information released by city water superintendent, Bernie Mathewly.

### Average Climbs

Grinnellians consumed water at a daily average of 604,000 gallons throughout the first 21 days of July while the average daily consumption for all of July in 1954 was lower by 3,000 gallons per day. Even though there are many more water-type air conditioners in use throughout Grinnell now than there were at this time last year, the record 875,000 gallons used on July 12th, 1954, has not yet been equaled. However, average daily figures are over those for last year. Peak day for this year was July 7th when over 800,000 gallons of water were consumed.

### Daily Output

With the rising water output climbing at its present rate, Grinnellians can plan on using almost 20,000,000 gallons of water during July alone. Figures for the seven day period July 15 through 21 show an average daily pumping output of 647,000 gallons:

Date	Daily Output
July 15	629,000
July 16	376,000
July 17	534,000
July 18	667,000
July 19	689,000
July 20	734,000
July 21	702,000

As indicated by the above figures, the 700,000 gallon daily mark has twice been exceeded during the most recent hot spell

JUL 14 1955

# Nine Week Salvage Attempt Success

## Drill Pulled To Surface Wednesday

Crew Sought Bit Since It Broke Early In May

A long-lost steel drill, buried 2200 feet below the surface in Grinnell's new \$113,000 city water well, has been pulled to the surface.

It ended a nine week search for the drill which was lost in early May as the Thorpe Well company began drilling on the last five hundred feet of the well.

The drill was pulled to the surface early Wednesday morning without the slightest trouble, after the crew succeeded in lowering a steel friction cylinder over the heavy steel bit.

During the nine week period, in which the company had reached the point of considering abandoning the project, several different approaches were used in an attempt to free the drill which had lodged against the side of the well hole 2200 feet under ground.

### Drill Along Side

Late Tuesday the crew succeeded in freeing the bit from the side of the hole after drilling along the side with a smaller six inch drill. When the bit moved over into the hole, the cylindrical friction unit slipped over the top and grasped the bit.

the company, along with Guy Elam, crew superintendent, directed the rescue operations. Allen then cut the cylinder free to remove the bit.

### Stem Broken


On inspection, the crew learned that the bit had sustained a heavy pounding after breaking loose nine weeks ago this Fri-

day. A portion of the broken stem had been milled off to enable the friction casing to slip over the neck and grasp the bit.

At the well site are a variety of special tools designed specifically to free the bit in Grinnell's new well. Allen estimated that \$1,000 worth of tools were

ruined or partially wrecked in the salvage operation. That along with the nine weeks of searching proved costly to the company.

It is estimated that a month to six weeks will be required to complete the drilling. The company is drilling a 12 inch hole the final 500 feet.



**FREEING A DRILL**—Carl Allen, right, directs crewmen in freeing a drill, pulled from a 2200 foot level at the new city water well, from a cylindrical friction pipe used in freeing the bit. Pictured are Guy Elam, O. A. Dandven and Bob Baker.

Carl Allen, trouble shooter for

AUG 11 1955

# New Well to Go Below 2,700 Feet

## Seek Water Bearing Strata Below Shale

At Special Session,  
Council Votes Approval;  
Wait Geological Analysis

Meeting in special session Tuesday noon the Grinnell city council authorized City Manager M. B. Starr to order resumption of drilling beyond the 2,700 foot mark if geological tests indicate that water bearing strata will be reached within another 100 feet.

The move was taken by the council with the possibility that the water supply could be greatly increased if another water bearing strata would be reached.

Soil samples were sent to the geological survey department at Iowa University at Iowa City Tuesday afternoon for analysis and recommendation by the geologists. Decision to continue drilling depends upon the geological findings.

Thorpe Well Company reached the prescribed 2,700 mark Tuesday morning and ceased drilling. The company was in a shale (non water bearing) formation at that level. It was believed that another water bearing strata would be reached within another 100 feet.

En route to the depth, two water bearing formations were encountered the principal one being in the Jordan strata. Another smaller formation was reached below the Jordan level.

Cost of the additional drilling to the city will be \$15 a foot or an estimated \$1,500 for the 100 feet. The go-ahead was voted by all six members of the council.

Carl Allen, representative of the drilling firm, pointed out that the shale formation is not water bearing. He told councilmen that the 200-foot shale formation would tend to crumble and that a 10-inch casing should be inserted to maintain the present hole, whether drilling continues or ceases.

It was decided also that before drilling is continued, that a test of the current water supply be conducted.

Allen told councilmen that the drillers are certain that they have gone through or are near the end of the shale formation. He said the shale has caved in during drilling and will again unless a casing is inserted.

Starr called for the special council meeting pointing out that the city is not getting the results it wanted. If further drilling or testing is to be done, now is the time, he pointed out.

Councilmen recalled that the 2,700 foot level was originally determined as a possibility of hitting softer water. Other city wells are to a maximum depth of 2,500 feet.

## Continued Drilling Is Authorized

Geological Check  
Indicates Water Is  
75 to 150 Feet Deeper

Lining of No. 7 well started this morning as plans are being completed for drilling another 100 feet or so to hit a new water bearing strata.

The action was authorized by City Manager M. B. Starr after learning results of a geological check of the well.

In authorizing the additional drilling, Starr had this to say:

"The new No. 7 well is now down to 2700 feet, according to the original plan. Although tests have not been completed we feel sure it will furnish adequate water for present day needs.

"However, after studying available data and consulting with Engineers of the Iowa Geological Survey, and with other well experts, it is my opinion that we can increase the capacity of the well considerably by drilling some farther; probably between 75 and 150 feet, and at only a 2% or 3% increase in cost.

"It would seem logical that by increasing the available supply we may delay the time when another well may be needed. Also, there is data that indicates that water from the next

lower water bearing stratum contains less hardness, which would somewhat reduce the cost of softening.

"Water usage has increased greatly, and will continue to increase with the further development of our city. We should not overlook an opportunity to anticipate the need for an additional supply."

Grinnell (Powers) 11/55



Grinnell (Poweshick)

**IOWA PRESS  
CLIPPING BUREAU**

Des Moines, Iowa

Herald-Register  
Grinnell, Iowa

SEP 16 1954

# Drillers Near 200 Foot Mark At New Well

Drillers expect to hit the 200 foot mark this week en route to a 2,700 foot depth on the city's new water well.

Tuesday, after a week of drilling, the company had passed the 152 foot mark. Later this week the company's largest drilling machine will be set up on the site on south West street to continue the task.

Working around the clock drillers have averaged nearly 30 feet a day, sometimes more and sometimes considerably less. On one shift early this week, the crew gained only two feet when rocks jammed the exhaust pipe.

Thorpe Well Company of Des Moines has contract for the \$113,000 project, which is expected to be completed by December 1955.



**DRILL POUNDS DEEPER**—Dick Kunkle and Guy Lemar, both of Stewart, Ia., were drill operators when this picture was taken at the site of the new city water well. Drillers have been averaging about 30-feet per day with 2,700 depth foot as the goal.

**IOWA PRESS  
CLIPPING BUREAU**

Des Moines, Iowa

Herald-Register  
Grinnell, Iowa

OCT 28 1954

## Drilling Resumes On New Water Well at Grinnell

Drilling has been resumed on the new water well for Grinnell.

Bernie Matherly, water superintendent, said the company's large drilling rig has been set up and drilling is again underway. The crew had passed the 200 foot mark Wednesday.

Drilling had been halted for nearly a month, when the company stopped operations with a smaller drill unit intending to put the larger drill into operation.

Matherly disclosed too that there has been no word from the crew that is to paint the inside of the Grinnell water tower. The project, according to contract let three weeks ago, calls for a Nov. 1 completion date.

EHW  
JBC  
CS

MEMORANDUM

To: H. G. Hershey  
From: J. B. Cooper  
August 11, 1955

Re: Developments at Grinnell City Well

N. B. Starr, City Manager, called 8/9/55 to report well now being drilled for Grinnell down to contract depth of 2700'. Bottom formation shale. Starr was undecisive about stopping at 2700' or drilling deeper and wanted our advice. I suggested samples be brought to us before we could tell him much. Samples were brought to Iowa City about 4:30 p. m.

Starr called 8/10/55. Samples not studied yet. Starr had talked to Thorpe and Thorpe had recommended deeper drilling. Decision was made by them to case out shale and drill deeper.

I called Thorpe Well Company about another matter and was informed by Carl Allen (Field foreman) that plans were to set 200' of 10" liner from 2702½' to 2502½'. to case out shale. Then a pump test would be conducted. Then the well would be drilled deeper (to Basement rocks) and another pump test run. This procedure sounds alright to me. Thorpe will notify us when first pump test is made.

When samples are studied I will call Starr and give him our best estimate of section below 2700'

John

*Handwritten initials*

August 12, 1955

Mr. N. B. Starr  
City Manager  
Grinnell, Iowa

Dear Mr. Starr:

We have examined the samples to a depth of 2700 feet, from the deep well now being drilled for the city of Grinnell.

As you know wells of this depth are rare in Iowa. It is difficult to predict the character, thickness, or water-bearing properties of the formations which will be encountered by drilling below a depth of 2700 feet at Grinnell.

We have compared the log of your well with the log of the deep well at Nevada. If geologic conditions at Grinnell are similar to those at Nevada, which may not be, the following geologic section may be anticipated.

<u>Formation and Character</u>	<u>Thickness (ft.)</u>	<u>Depth Range (ft.)</u>
<b>Cambrian system</b>		
<b>Dresbach formation</b>		
Eau Claire member (Dolomite, silty, may contain some shale)	115	2700-2815
Mt. Simon member (Sandstone)	105	2815-2920
<b>Pre-Cambrian system</b>		
<b>Red Clastics</b>		
(Sandstone, mica, feldspar; may be redder in color than sandstone above)		2920-



*P. W. ...*

November 24, 1953

Mr. C. W. Durham  
Henningson, Durham & Richardson, Inc.  
2962 Harney Street  
Omaha 2, Nebraska

Dear Mr. Durham:

We are replying to your letter of November 17 requesting information on the city water supply at Grinnell, Iowa, and pertinent comments relative to the construction of an additional deep well. The available data from the files of the cooperative investigations of the Iowa and U. S. Geological Surveys are summarized as follows:

The Grinnell city water supply is derived from two deep wells No. 5 and No. 6, 2260 and 2498 feet deep respectively, located at the city water pumping station at Second and Main Streets. Wells 1, 2, 3, and 4 have all been abandoned. Well 4, a 2000-foot hole, was plugged up about three years ago to decrease the possibility of contamination of the deep aquifers. The following geologic section was encountered in the drilling of Well 6. All depth figures are referred to the altitude of the well curb 1020 feet above sea level.

<u>Formation and description</u>	<u>Thickness (ft.)</u>	<u>Depth (ft.)</u>	
		<u>From</u>	<u>To</u>
<b>Pleistocene</b>			
No samples (pebbly clay with sand at base)	200	0	200
<b>Mississippian system</b>			
St. Louis limestone (sandy limestone)	30	200	230
Keokuk formation (cherty dolomite)	68	230	298
Burlington limestone	42	298	340
Hampton formation (cherty dolomite and limestone)	50	340	390
English River siltstone	30	390	420
Maple Mill shale	130	420	550

Mr. N. B. Starr

2

August 12, 1955

The well at Nevada penetrated the Red Clastics for a distance of 235 feet.

We are very much interested in this well and will be glad to aid you in any way we can.

Very truly yours,

H. G. Hershey

HGH:JBC:L

*Powdermill*

September 27, 1955

Mr. Bernard Matherly  
Water Superintendent  
Grinnell, Iowa

Dear Mr. Matherly:

Enclosed is a report on the mineral analysis  
of water from your 2702-foot well as shown by a  
sample collected by you August 30, 1955.

If you have any questions concerning this  
report, please do not hesitate to let me hear from  
you.

Very truly yours,

H. G. Hershey  
by C. N. Brown

HGH:L  
Enc.



Powshiek

September 27, 1955

Mr. M. B. Starr  
City Manager  
Grinnell, Iowa

Dear Mr. Starr:

Enclosed is a report on the mineral analysis of water from your 2702-foot well as shown by a sample collected by Mr. B. Matherly August 30, 1955.

If you have any questions concerning this report, please do not hesitate to let me hear from you.

Very truly yours,

H. G. Hershey  
by C. N. Brown

HGH:L  
Enc.

check through these and let me  
know the range of samples included.

after getting a cut for Dick keep  
the rest handy until I find out for  
sure whether or not the city wants  
a set of the samples

Gale

Missing

240-245

230-233

~~233~~ - 236

236-240

182-185

355-360 - 2

430-435 - 2

435-440 - 2

440-445 - 2

695-700 - 2

830-835 - 2

885-890 - 2



Poweshiek

MEMORANDUM

October 6, 1955

To: H. G. Hershey  
From: J. B. Cooper  
Re: Grinnell City Well

Bernard Matherly called to report Grinnell City well now at depth of 2968'. Sandstone from 2865 to 2968'. Extremely hard formations at 2968' -- driller unable to penetrate more than a few inches and no sample recovery.

Hard formation probably is top of Precambrian quartzite or granite.

Dick Northup went to Grinnell about 1:00 p. m. to pick up samples and attempt to identify bottom formation (if any sample had been obtained).

SWL dropped 32' at depth of 2875' Driller reports water sand from 2865 - 2968'

*Jim*



MEMORANDUM

October 7, 1955

To: H. G. Hershey  
From: Richard C. Northup  
Subject: Grinnell City Well

A trip was made to Grinnell on October 6 at request of the city officials to check on the New City Well. Apparently the Mt. Simon sandstone had been reached at 2865 feet with a drop in the water head of 32 feet, <sup>at 2968'</sup> fine-grained, very hard sandstone was reached. This may be quartzite, although the last sample from 2968-2970 feet shows both rounded and sharp angular grains. A better check can be made here with a clean dried sample. At any rate Messrs. Godfrey and Starr, Mayor and city manager respectively have decided to stop drilling. A pumping test will be run sometime next week, perhaps Tuesday or Wednesday, and they will notify us in time for someone to be there. You will recall that a pumping test was run earlier to include water from the Prairie du Chien, Jordan, and St. Lawrence formations, and which yielded 1015 gallons per minute.

H

---

~~Gerontology -  
Harris at Noon  
Install reservoir.  
Horvath.  
Howard Hill  
28171  
Merv. Meade, V.P.  
Long Range.  
Webster 9600~~

**MEMORANDUM**

**October 7, 1955**

**To: H. G. Hershey  
From: Richard C. Northup  
Subject: Grinnell City Well**

A trip was made to Grinnell on October 6 at request of the city officials to check on the New City Well. Apparently the Mt. Simon sandstone had been reached at 2865 feet with a drop in the water head of 32 feet, <sup>at 2865'</sup> fine-grained, very hard sandstone was reached. This may be quartzite, although the last sample from 2968-2970 feet shows both rounded and sharp angular grains. A better check can be made here with a clean dried sample. At any rate Messrs. Godfrey and Starr, Mayor and city manager respectively have decided to stop drilling. A pumping test will be run sometime next week, perhaps Tuesday or Wednesday, and they will notify us in time for someone to be there. You will recall that a pumping test was run earlier to include water from the Prairie du Chien, Jordan, and St. Lawrence formations, and which yielded 1015 gallons per minute.

*Reviewed*

MEMORANDUM

October 7, 1955

To: Dr. H. G. Hershey  
From: R. C. Northup  
Re: Bottom hole samples from Grinnell City Well

The samples from <sup>2968-2970'</sup>~~3968'-3970'~~ at Grinnell were studied and the well has apparently reached a hard quartzite or quartzitic sandstone with little or no porosity. While the cuttings are very pulverized, they are for the most part very sharp and angular, probably not true grains, but pieces that have broken across the grain. The overall color is a light pink, and the surfaces are very vitreous. If the underlying formations are similar, there would probably be little or no more water ~~RECOVERED~~<sup>RECOVERED</sup>. Inasmuch as an increased supply of water has already been indicated from the sandstone above the quartzitic material, and as shale from the Franconia-Eau Claire section has caused some trouble from caving, the city manager and mayor feel it advisable to set liner through the remaining open shale section from about 2785' to 2803' and complete with pumping test next week.

*Bowling*

October 14, 1955

**Mr. T. W. Thorpe  
Thorpe Well Company  
2340 Sixth Avenue  
Des Moines, Iowa**

**Dear Mr. Thorpe:**

**Enclosed please find a copy of the report  
mailed to you September 27, 1955 of Well No. 7  
which you drilled for the city of Grinnell.**

**If you have any questions concerning this  
report, please do not hesitate to let me hear from  
you.**

**Very truly yours,**

**H. G. Hershey**

**HGH:L**

**Enc.**



*P. Westrich*

September 27, 1955

Thorpe Well Company  
2340 Sixth Avenue  
Des Moines, Iowa

Gentlemen:

Enclosed is a report on the mineral analysis of water from the 2702-foot well you drilled for the city of Grinnell as shown by a sample collected by Mr. Matherly August 30, 1955.

If you have any questions concerning this report, please do not hesitate to let me hear from you.

Very truly yours,

H. G. Hershey  
by C. N. Brown

HGH:L  
Enc.

NOV 17 1955

# Plug New Well At 2,550 Feet; Production Tests Commenced

At a special meeting Monday afternoon, Grinnell city officials authorized the Thorpe Well Company to plug the new city well at 2,550 feet and prepare it for another production test.

The drilling had reached a depth of 2,970 feet when further drilling was halted.

At the 2,550 level, the well will be sealed off, drilling equipment removed and per-

forated pipe inserted. Water developing chemicals will be added to the water veins and pumping tests will be commenced.

It is estimated that the production tests will yield 1,200 gallons of water per minute.

Should the tests prove satisfactory, the new well will be put into use thus enlarging the water supply of Grinnell.

support of the work of the Pro

March 25, 1963

Mr. Arthur J. Bader  
Stanley Engineering Company  
Stanley Building  
Muscatine, Iowa

Dear Mr. Bader:

We are replying to your letter of March 20 concerning the geologic log of Grinnell city well No. 7 (1955) and additional information on the ground-water conditions there as an aid in developing a water supply of approximately 1000 gpm for industrial use.

A generalized log of the formations encountered in this well and pertinent information on the construction and production of the well are summarized on separate sheets appended to this letter. Currently the city has one other deep well in operation in the near vicinity of well No. 7 and may have a third well for standby use.

According to your letter an industrial site has been chosen that is approximately three-quarters of a mile south of the Grinnell city wells. This places it at the south edge of town in the NW $\frac{1}{4}$  NW $\frac{1}{4}$  sec. 21, T. 80N., R. 16W. just off Highway 146 and probably near the Minneapolis and St. Louis railway. A new deep well at this location is expected to penetrate practically the same sequence of formations as found in city well No. 7 with some slight modifications owing to local variations in the structure and thickness of the strata.

Only small to moderate quantities of water are expected from the upper and intermediate formations in this area. Moreover, the water from the Devonian and Silurian rocks probably will be highly mineralized in sulfate because of the associated gypsum.

The Prairie du Chien - Jordan - St. Lawrence Formations at a depth range of approximately 2000 to 2500 feet are the chief sources of supply in the Grinnell city wells. Tests indicate these wells to be capable of producing between 650 and 875 gpm or more with specific capacities ranging between 7 and 10 gallons per foot drawdown. All three wells are cased from the surface at least into the upper part of the Prairie du Chien Dolomite to shut out highly mineralized water in the overlying beds. The static water level of the Jordan aquifer is estimated to be about

Mr. Arthur J. Bader

- 2 -

March 25, 1963

285 feet below the surface at the contemplated drilling site south of Grinnell.

The quality of the water from the Grinnell city wells is shown on the attached mineral analysis sheet. These analyses indicate the water to be acceptable for drinking and general industrial use. The water temperature should be about 75 to 76° F.

On this basis we conclude that the Jordan Sandstone and associated dolomite strata between 2000 and 2500 feet are the most promising sources for a large capacity well yielding at least 1000 gpm of potable water at Grinnell. It would seem advisable to have the new well cased from the surface for about 50 feet into the Prairie du Chien Dolomite and the casing grouted in place for its full length with neat cement to assure a good seal and to protect the pipe from corrosion. Acidizing and developing the well for a considerable period may appreciably increase the original output.

We hope this is the information you wished and that it will assist you with your study of industrial water supply at Grinnell. If there are any questions remaining or if we can provide you further information on this matter, please let us know.

Very truly yours,

H. G. Hershey

HGH/PJH  
bjm  
Enclosures



**GEOLOGIC LOG GRINNELL CITY WELL NO. 7 (1955)**

<u>Formation</u>	<u>Thickness(ft.)</u>	<u>Depth Range(ft.)</u>
<b>Quaternary System</b>		
Pleistocene Series (glacial drift, locally some sand and gravel)	230	0-230
<b>Mississippian System</b>		
Keokuk-Burlington Formations (limestone and dolomite, con- siderable chert)	102	230-332
Hampton Formation (limestone and dolomite, chert zone in lower part)	48	332-380
North Hill Formation (limestone and dolomite)	30	380-410
Prospect Hill Siltstone and shale	5+	410-415
Maple Mill Shale	145	415-560
<b>Devonian System</b>		
Lime Creek Formation (upper part limestone and dolomite, lower 2/3's calcareous shale, some dolomite)	130	560-690
Cedar Valley Formation (mostly limestone in upper 1/3, dolomite in lower 2/3's; considerable gypsum - anhydrite in middle; some chert at base of middle; trace shale)	300	690-990
Wapsipinicon Formation (upper 50+ mostly gypsum-anhydrite, some dolo- mite; chert, limestone and dolomite in lower 120+)	175	990-1165
<b>Silurian System</b>		
Undifferentiated dolomite	25	1165-1190
<b>Ordovician System</b>		
Maquoketa Formation (shale, dolomitic)	210	1190-1400
Galena Formation (dolomite, lower part contains 5-30% chert)	230	1400-1630
Decorah-Platteville Formations (limestone and shale at top, under- lain by dolomite; Glenwood Shale at base)	63	1630-1693
St. Peter Sandstone	34	1693-1727
<b>Prairie du Chien Formation</b>		
Willow River Member (dolomite, sandy)	168	1727-1895
Root Valley Member (sandy dolomite and sandstone, about 50-50%)	80	1895-1975
Onecta Member (dolomite, some chert)	217	1975-2192

**Geologic Log Grinnell City Well No. 7 (1955) (continued)**

<u>Formation</u>	<u>Thickness(ft.)</u>	<u>Depth Range(ft.)</u>
<b>Cambrian System</b>		
Jordan Sandstone	55	2192-2247
St. Lawrence Formation (dolomite, slightly silty, glauconitic in lower half)	261	2247-2508
Franconia Formation (upper half mostly fine sandstone with considerable shale and dolomite, very glauconitic; lower half mostly shale, some dolomite)	290	2508-2798
Dresbach Formation (upper part dolomite with glauconite; lower part sandstone; basal 15 feet may be metamorphosed Precambrian sediments?)	172	2798-2970



**Name:** Grinnell city well No. 7 (1955)

**Location:** SW $\frac{1}{2}$  NW $\frac{1}{2}$  sec. 16, T. 80N., R. 16W. Poweshiek County, Iowa

**Elevation:** 1011' above sea level

**Contractor:** Thorpe Well Company, Des Moines

**Drilling dates:** September 1954-November 1955

**Depth:** Original 2970'; plugged back to 2550', November 1955

**Casing record:** 700' of 19" casing from 0-700' cemented in; 1325' of 12" liner from 675-2000' cemented in; 710' of 10" liner from 1975-2685'; well plugged back to 2550' and casing perforated opposite Jordan and St. Lawrence Formations.

**Production data:** On January 22, 1960 a pumping test of 30 minutes duration produced 875 gpm with 86 feet of drawdown from a static water level of 298 feet. Specific capacity is 10 gallons/foot drawdown. Pump setting reported to be at 500'.



# STANLEY ENGINEERING COMPANY

CONSULTING ENGINEERS

March 20, 1963

STANLEY BUILDING  
MUSCATINE, IOWA

IOWA GEOLOGICAL SURVEY

MAR 21 1963

Iowa State Geological Survey  
Iowa City, Iowa

Gentlemen:

We have been retained by the City of Grinnell, Iowa, to make a study concerning the development of an industrial ground water supply of approximately 1,000 gallons per minute. The new well will be approximately three-quarters of a mile south of a 1,000 gallon per minute, 3,000 ft. deep well constructed by the city in 1955. We were not, however, able to obtain copies of the boring logs or pumping tests for this existing well.


*estimate*  
*NW 1/4 sec. 21 -*  
*80 N - 16 W.*

If possible, we would like to obtain any information your office would have concerning the above-mentioned well, plus any additional information or recommendations concerning ground water supplies in this area.

We would appreciate your early reply.

Yours very truly,

STANLEY ENGINEERING COMPANY

  
Arthur J. Bader

AJB:rjc:3468

Telephone  
AMherst  
3-9494

**GEOLOGIC LOG GRINNELL CITY WELL NO. 7 (1959)**

<u>Formation</u>	<u>Thickness(ft.)</u>	<u>Depth Range(ft.)</u>
<b>Quaternary System</b>		
Pleistocene Series (glacial drift, locally some sand and gravel)	230	0-230
<b>Mississippian System</b>		
<b>Keokuk-Burlington Formations</b>		
(limestone and dolomite, con- siderable chert)	102	230-332
Hampton Formation (limestone and dolomite, chert zone in lower part)	48	332-380
North Hill Formation (limestone and dolomite)	30	380-410
Prospect Hill Siltstone and shale	5+	410-415
Maple Mill Shale	145	415-560
<b>Devonian System</b>		
Lime Creek Formation (upper part limestone and dolomite, lower 2/3's calcareous shale, some dolomite)	130	560-690
Cedar Valley Formation (mostly limestone in upper 1/3, dolomite in lower 2/3's; considerable gypsum - anhydrite in middle; some chert at base of middle; trace shale)	300	690-990
Wapsipinicon Formation (upper 50+ mostly gypsum-anhydrite, some dolo- mite; chert, limestone and dolomite in lower 120+')	175	990-1165
<b>Silurian System</b>		
Undifferentiated dolomite	25	1165-1190
<b>Ordovician System</b>		
Maquoketa Formation (shale, dolomitic)	210	1190-1400
Galena Formation (dolomite, lower part contains 5-30% chert)	230	1400-1630
<b>Deerch-Platteville Formations</b>		
(limestone and shale at top, under- lain by dolomite; Glenwood Shale at base)	63	1630-1693
St. Peter Sandstone	34	1693-1727
<b>Prairie du Chien Formation</b>		
Willow River Member (dolomite, sandy)	168	1727-1895
Root Valley Member (sandy dolomite and sandstone, about 50-50%)	80	1895-1975
Onecta Member (dolomite, some chert)	217	1975-2192

**Geologic Log Grinnell City Well No. 7 (1955) (continued)**

<u>Formation</u>	<u>Thickness(ft.)</u>	<u>Depth Range(ft.)</u>
<b>Cambrian System</b>		
<b>Jordan Sandstone</b>	<b>55</b>	<b>2192-2247</b>
<b>St. Lawrence Formation (dolomite, slightly silty, glauconitic in lower half)</b>	<b>261</b>	<b>2247-2508</b>
<b>Franconia Formation (upper half mostly fine sandstone with considerable shale and dolomite, very glauconitic; lower half mostly shale, some dolomite)</b>	<b>290</b>	<b>2508-2798</b>
<b>Drebach Formation (upper part dolomite with glauconite; lower part sandstone; basal 15 feet may be metamorphosed Precambrian sediments?)</b>	<b>172</b>	<b>2798-2970</b>

IOWA GEOLOGICAL SURVEY  
 TABULATION OF WATER ANALYSIS  
 (Dissolved constituents in parts per million)

Town - Well No Owner	Date of coll.	Depth (ft.)	Geol. source	Sp F	Liss. solids	Fe	Mn	Ca	Mg	K	Na	CO <sub>3</sub>	HCO <sub>3</sub>	SO <sub>4</sub>	Cl	F	NO <sub>3</sub>	Hardness			pH	Cond
																		cal.	as carb.	non- carb.		
Grinnell city No. 5 (1915)	7/26/60	2260	Pr du ch Jordan	76	763	.66	<.05	81	40	20	103	0	368	285	18	1.5	<.01	364	302	62	7.3	130
" " No. 6 (1926)	"	2500	Pr. du ch Jordan St. Law.	76	933	.54	<.05	95	43	20	133	0	368	391	24	1.5	1.0	445	302	113	7.4	130
" " No. 7 (1955)	1/22/60	2550	"	75	728	.58	<.05	79	40	20	99	0	371	258	21	1.4	<.01	362	304	58	7.7	130

NOTES:



**Name:** Grinnell city well No. 7 (1955)

**Location:** SW $\frac{1}{2}$  NW $\frac{1}{2}$  sec. 16, T. 80N., R. 16W. Poweshiek County, Iowa

**Elevation:** 1011' above sea level

**Contractors:** Thorpe Well Company, Des Moines

**Drilling dates:** September 1954–November 1955

**Depth:** Original 2970'; plugged back to 2550', November 1955

**Casing record:** 700' of 19" casing from 0–700' cemented in; 1325' of 12" liner from 675–2000' cemented in; 710' of 10" liner from 1975–2685'; well plugged back to 2550' and casing perforated opposite Jordan and St. Lawrence Formations.

**Production data:** On January 22, 1960 a pumping test of 30 minutes duration produced 875 gpm with 86 feet of drawdown from a static water level of 298 feet. Specific capacity is 10 gallons/foot drawdown. Pump setting reported to be at 500'.

**GEOLOGIC LOG GRINNELL CITY WELL NO. 7 (1955)**

<u>Formation</u>	<u>Thickness(ft.)</u>	<u>Depth Range(ft.)</u>
<b>Quaternary System</b>		
Pleistocene Series (glacial drift, locally some sand and gravel)	230	0-230
<b>Mississippian System</b>		
Keokuk-Burlington Formations (limestone and dolomite, con- siderable chert)	102	230-332
Hampton Formation (limestone and dolomite, chert zone in lower part)	48	332-380
North Hill Formation (limestone and dolomite)	30	380-410
Prospect Hill Siltstone and shale	5+	410-415
Maple Mill Shale	145	415-560
<b>Devonian System</b>		
Lime Creek Formation (upper part limestone and dolomite, lower 2/3's calcareous shale, some dolomite)	130	560-690
Cedar Valley Formation (mostly limestone in upper 1/3, dolomite in lower 2/3's; considerable gypsum - anhydrite in middle; some chert at base of middle; trace shale)	300	690-990
Wapsipinicon Formation (upper 50+ mostly gypsum-anhydrite, some dolo- mite; chert, limestone and dolomite in lower 120+')	175	990-1165
<b>Silurian System</b>		
Undifferentiated dolomite	25	1165-1190
<b>Ordovician System</b>		
Maquoketa Formation (shale, dolomite)	210	1190-1400
Galena Formation (dolomite, lower part contains 5-30% chert)	230	1400-1630
Decorah-Platteville Formations (limestone and shale at top, under- lain by dolomite; Glenwood Shale at base)	63	1630-1693
St. Peter Sandstone	34	1693-1727
<b>Prairie du Chien Formation</b>		
Willow River Member (dolomite, sandy)	168	1727-1895
Root Valley Member (sandy dolomite and sandstone, about 50-50%)	80	1895-1975
Onota Member (dolomite, some chert)	217	1975-2192

**Geologic Log Grinnell City Well No. 7 (1955) (continued)**

<u>Formation</u>	<u>Thickness(ft.)</u>	<u>Depth Range(ft.)</u>
<b>Cambrian System</b>		
<b>Jordan Sandstone</b>	<b>55</b>	<b>2192-2247</b>
<b>St. Lawrence Formation (dolomite, slightly silty, glauconitic in lower half)</b>	<b>261</b>	<b>2247-2508</b>
<b>Franconia Formation (upper half mostly fine sandstone with considerable shale and dolomite, very glauconitic; lower half mostly shale, some dolomite)</b>	<b>290</b>	<b>2508-2798</b>
<b>Dresbach Formation (upper part dolomite with glauconite; lower part sandstone; basal 15 feet may be metamorphosed Precambrian sediments?)</b>	<b>172</b>	<b>2798-2970</b>





**Name:** Grinnell city well No. 7 (1955)

**Location:** SW $\frac{1}{2}$  NW $\frac{1}{2}$  sec. 16, T. 80N., R. 16W. Poweshiek County, Iowa

**Elevation:** 1011' above sea level

**Contractor:** Thorpe Well Company, Des Moines

**Drilling dates:** September 1954-November 1955

**Depth** Original 2970'; plugged back to 2550', November 1955

**Casing record:** 700' of 19" casing from 0-700' cemented in; 1325' of 12" liner from 675-2000' cemented in; 710' of 10" liner from 1975-2685'; well plugged back to 2550' and casing perforated opposite Jordan and St. Lawrence Formations.

**Production data:** On January 22, 1960 a pumping test of 30 minutes duration produced 875 gpm with 86 feet of drawdown from a static water level of 298 feet. Specific capacity is 10 gallons/foot drawdown. Pump setting reported to be at 560'.

IOWA GEOLOGICAL SURVEY  
Water Analysis Report  
Iowa City, Iowa

County Pow Date Sampled \_\_\_\_\_  
 Town Grinnell Sampled by \_\_\_\_\_  
 Location of well \_\_\_\_\_ sec. \_\_\_\_\_, T. \_\_\_\_\_ N., R. \_\_\_\_\_ Twp \_\_\_\_\_  
 Owner \_\_\_\_\_ Well No. \_\_\_\_\_ Depth \_\_\_\_\_ Ft. \_\_\_\_\_  
 Type of well \_\_\_\_\_ Static level \_\_\_\_\_ Ft. \_\_\_\_\_ Altitude \_\_\_\_\_ Ft. \_\_\_\_\_  
 Producing Formation(s) \_\_\_\_\_ Depth Range \_\_\_\_\_

Notes on condition of well, casing, or formations.

Dissolved constituents and properties (in parts per million except as indicated):

Silica (SiO <sub>2</sub> )	<u>J &amp; M. S. Jordan</u>		Dissolved solids	<u>1230</u>	<u>885</u>
Iron (Fe)	<u>0.02</u>	<u>1.3</u>	Hardness (calc. as CaCO <sub>3</sub> )		
Manganese (Mn)	<u>0.04</u>	<u>0.05</u>	Total	<u>454</u>	<u>382</u>
Calcium (Ca)	<u>111</u>	<u>87</u>	(as grains per gallon)		
Magnesium (Mg)	<u>43</u>	<u>40</u>	Carbonate	<u>286</u>	<u>286</u>
Potassium (K)	<u>32</u>	<u>19</u>	Noncarbonate	<u>168</u>	<u>96</u>
Sodium (Na)	<u>255</u>	<u>115</u>	Alkalinity (as CaCO <sub>3</sub> )	<u>286</u>	<u>286</u>
Carbonate (CO <sub>3</sub> )	<u>NONE</u>		pH	<u>7.7</u>	<u>7.8</u>
Bicarbonate (HCO <sub>3</sub> )	<u>349</u>	<u>349</u>	Specific Conductance		
Sulfate (SO <sub>4</sub> )	<u>372</u>	<u>306</u>	(micromhos at 25°C.)	<u>1930</u>	<u>1245</u>
Chloride (Cl)	<u>245</u>	<u>47</u>	Temperature (°F.)	<u>75°</u>	<u>75°</u>
Fluoride (F)	<u>1.4</u>	<u>1.5</u>	*****		
Nitrate (NO <sub>3</sub> )	<u>0</u>	<u>0</u>	Analysis No.		
Remarks:			Date analyzed	<u>10-27-55</u>	<u>8-30-55</u>
			I. G. S. Well No.		

## **Resume of Grinnell Pump Test Well No. 7**

**August 27, 1955**

Well pumped total of 6 hours 25 minutes at rates varying from 480 to 692 g. p. m. — Drawdown was about 80 feet to a pumping level of 381 feet.

**August 29, 1955**

Well pumped total of 12 hours at rate varying from 680 to 930 g. p. m. Drawdown was about 143 feet to a pumping level of 444 feet.

**August 30, 1955**

Well pumped total of 5 hours 48 minutes at rates varying from 500 to 1015 g. p. m. — Drawdown was about 175 feet to a pumping level of 475 feet.

In all tests the well was not pumped long enough at each rate of discharge to establish definitely the pumping level for that discharge rate.

Well No. 7 is 745 feet distant from City Water plant, the site of Wells 5 and 6. During test of Well 7 Wells 5 and 6 were pumped at different times. Well 6 reported to pump at 685 g. p. m. and Well 5 at 300 g. p. m. The pumping level in Well 6 during pumping of Well 7 was about 394 feet. The water level in Well 6 with Wells 5 and 7 pumping was about 319 feet. The water level in Well 6 with Well 6 and 5 pumping, but well 7 off was about 399 feet. The drawdown in No. 7 with Wells No. 5 and 6 pumping was 10 feet.

EHW  
013

## Resume of Grinnell Pump Test Well No. 7

August 27, 1955

Well pumped total of 6 hours 25 minutes at rates varying from 480 to 692 g.p.m. — Drawdown was about 80 feet to a pumping level of 381 feet.

August 29, 1955

Well pumped total of 12 hours at rate varying from 680 to 930 g.p.m. Drawdown was about 143 feet to a pumping level of 444 feet.

August 30, 1955

Well pumped total of 5 hours 48 minutes at rates varying from 500 to 1015 g.p.m. — Drawdown was about 175 feet to a pumping level of 475 feet.

In all tests the well was not pumped long enough at each rate of discharge to establish definitely the pumping level for that discharge rate.

Well No. 7 is 745 feet distant from City Water plant, the site of Wells 5 and 6. During test of Well 7 Wells 5 and 6 were pumped at different times. Well 6 reported to pump at 685 g.p.m. and Well 5 at 300 g.p.m. The pumping level in Well 6 during pumping of Well 7 was about 394 feet. The water level in Well 6 with Wells 5 and 7 pumping was about 319 feet. The water level in Well 6 with Well 6 and 5 pumping, but well 7 off was about 399 feet. The drawdown in No. 7 with Wells No. 5 and 6 pumping was 10 feet.

*Jm*



Results of Pumping Test  
Grinnell City Well No. 7  
August 27 to 30, 1955

Name: Grinnell City Well No. 7

Location: SW NW sec. 16, T. 80 N., 12. 16 W. Poweshiek County

Elevation: 1011 feet <sup>above</sup> ~~along~~ sea level datum

Contractor: Thorpe Well Company Des Moines, Iowa

Present Depth: 2702 feet

Casing Record: 19" casing cemented in hole from surface to about 2200 feet. 202' of 10" liner from 2500 to 2702' (present depth)

Test pump: Turbine. 490' of 12" column and 6-stage bowls with 18' of suction pipe on bottom. Powered with 2 large diesel motors.

Discharge Measurements: 6" Sparling meter set in discharge line. Discharge line was 10' of 10" pipe <sup>with</sup> ~~and~~ 15' of 6" pipe from pump. Majority of discharge measurements made by M. B. Starr, City Manager.

Temperature Measurements: Temperature measured at end of discharge line. Thermometer used by city registered 1° lower than the thermometer of the Geological Survey.


Depth-to-water measurements: Majority of depth-to-water measurements made by Bernard Matherly, Water Superintendent.

Remarks: City wells No's. 5 and 6 (745 feet distant) were pumped intermittently at rates of 300 g.p.m. and 685 respectively during pumping of well no. 7.

City Well No. 7 is to be drilled deeper to explore water possibilities of lower Cambrian sand stone.

Data collected during pumping test by J. B. Cooper, Geological Survey, Iowa City.

Note: It was impracticable to obtain precise and continuous d/w and gpm measurements inasmuch as inadequate provision was made for entrance of measuring device into casing. The measuring lines used periodically stuck between pump column and casing. Pumping rates were changed often and motor speeds varied.



**Results of Pumping Test  
Grinnell City Well No. 7  
August 27 to 30, 1955**

**Name: Grinnell City Well No. 7**

**Location: SW NW sec. 16, T. 80 N., 12. 16 W. Poweshiek County**

**Elevation: 1011 feet <sup>above</sup> ~~along~~ sea level datum**

**Contractor: Thorpe Well Company Des Moines, Iowa**

**Present Depth: 2702 feet**

**Casing Record: 19" casing cemented in hole from surface to about 2200 feet. 202' of 10" liner from 2500 to 2702' (present depth)**

**Test pump: Turbine. 490' of 12" column and 6-stage bowls with 18' of suction pipe on bottom. Powered with 2 large diesel motors.**

**Discharge Measurements: 6" Sparling meter set in discharge line. Discharge line was 10' of 10" pipe <sup>with</sup> and 15' of 6" pipe from pump. Majority of discharge measurements made by M. B. Starr, City Manager.**

**Temperature Measurements: Temperature measured at end of discharge line. Thermometer used by city registered 1° lower than the thermometer of the Geological Survey.**

**Depth-to-water measurements: Majority of depth-to-water measurements made by Bernard Matherly, Water Superintendent.**

**Remarks: City wells No's. 5 and 6 (745 feet distant) were pumped intermittently at rates of 300 g. p. m. and 685 respectively during pumping of well no. 7.**

**City Well No. 7 is to be drilled deeper to explore water possibilities of lower Cambrian sand stone.**

**Data collected during pumping test by J. B. Cooper, Geological Survey, Iowa City.**

**Note: It was impracticable to obtain precise and continuous d/w and gpm measurements inasmuch as inadequate provision was made for entrance of measuring device into casing. The measuring lines used periodically stuck between pump column and casing. Pumping rates were changed often and motor speeds varied.**

Results of Pumping Test  
Grinnell City Well No. 7  
October 12-13, 1955

Name: Grinnell City Well No. 7

Location: SW NW sec. 16, T. 80 N., R. 16 W. Poweshiek County

Elevation: 1011 feet above sea level

Contractor: Thorpe Well Company, Des Moines

Depth: ~~2920'~~ 2970'

Casing record: 19" casing cemented in hole from surface to about 2000'. *see final casing record on pump test results of 11/11/55.*

Test Pump: Turbine. 490' of 12" column and 6-stage bowls with 10' of suction pipe. Powered by 2 large diesel engines.

Discharge measurements: 6" Sparling meter set in discharge line. Discharge line was 10" with upturned 45° elbow at discharge end. Majority of measurements made by M. B. Starr, City Manager.

Temperature measurements: Made at end of discharge line.

Depth to water measurements: Majority made by Bernard Matherly, Water Superintendent.

Aquifer tested: Jordan and Mt. Simon sandstone.

Remarks: City well No. 5 was pumped at 300 g.p.m. continuously during pumping test.

Results: Drawdown was greater at comparable discharge rates than the drawdown of water from Jordan sandstone alone. (See pump test results of August 27-30, 1955).

Future plans: Liner will be set opposite the Jordan sandstone and pumping test conducted on water from the Mt. Simon sandstone.

Data collected: during pumping test by W. L. Steinhilber.

**Results of Pumping Test  
Grinnell City Well No. 7  
October 12-13, 1955**

**Name: Grinnell City Well No. 7**

**Location: SW NW sec. 16, T. 80 N., R. 16 W. Poweshiek County**

**Elevation: 1011 feet above sea level**

**Contractor: Thorpe Well Company, Des Moines**

**Depth: 2920'**

**Casing record: 19" casing cemented in hole from surface to about 2200'.**

**Test Pump: Turbine. 490' of 12" column and 6-stage bowls with 10' of suction pipe. Powered by 2 large diesel engines.**

**Discharge measurements: 6" Sparling meter set in discharge line. Discharge line was 10" with upturned 45° elbow at discharge end. Majority of measurements made by M. B. Starr, City Manager.**

**Temperature measurements: Made at end of discharge line.**

**Depth to water measurements: Majority made by Bernard Metherly, Water Superintendent.**

**Aquifer tested: Jordan and Mt. Simon sandstone.**

**Remarks: City well No. 5 was pumped at 300 g. p. m. continuously during pumping test.**

**Results: Drawdown was greater at comparable discharge rates than the drawdown of water from Jordan sandstone along. (See pump test results of August 27-30, 1955).**

**Future plans: Liner will be set opposite the Jordan sandstone and pumping test conducted on water from the Mt. Simon sandstone.**

**Data collected: during pumping test by W. L. Steinhilber.**



obs. - W.L.S.

9-280

UNITED STATES  
DEPARTMENT OF THE INTERIOR  
GEOLOGICAL SURVEY

File No. { Washington .....  
District .....

Grinnell City Well # 7

10/12/55

Time	R.P.M.		Pumping level	gpm	Temp.	Remarks
	Engine	Pump				
10:10a	725	1325	304-75	SWL		start pumping
10:30	"	"	371-0	402		
11:00	"	"	369	418	74°F	water muddy
11:30	"	"	367	429		do
12:00	"	"	367	433		water cloudy & sand
12:30	"	"	365-5	435		do
1:00	"	"	365-8	440	75°F	do
1:30	750	1400	386-8	530		do
2:00	"	"	386-11	525	75°F	do
2:30	"	"	385-2	530		do
3:00	800	1500	412-0	632		do water samples
3:30	"	"	411-10	634		do taken for
4:00	"	"	412-7	637		do chem. analysis
4:30	850	1550	444-9	720		do
5:00	"	"	445-2	720		do
5:30	"	"	445-2	710		do
6:30	"	"	445-6	710		do
7:00	900	1600	472-10	762		do
7:30	"	"	474-10	754	75°F	do
8:00	"	"	475-1	755		water clear
8:30	"	"	475-0	756		do
9:00	"	"	475-0	756		do
9:30	"	"	474-9	750		do
10:00	"	"	475-4	756		do
10:30	"	1625	482-6	777		do
11:00	"	"	482-6	780		do
11:30	910	1640	487-0	789		do
12:00	"	"	486-10	775		do
12:30	"	"	486-8	780		do
1:00	"	"	484-2	780		do
1:30	"	"	483-9	780		do
2:00	"	"	483-5	775		do

obs. W.L.S.



IOWA GEOLOGICAL SURVEY  
ROUTING SLIP

Staffs

IGS

- HGH  
 MDA  
 RPC  
 GJD  
 AJF  
 CMF  
 PJH  
 LFJ  
 RCN  
 RVR  
 GES

Disposition

- File  
 Prepare reply  
 Comment  
 Your attention  
 See me  
 Return  
 Initial

Remarks:

For. Files  
Nothings to be  
Sent out.

USGS

- JBC  
 EMH  
 RMJ  
 CWL  
 CRM

Sample Room

From: Jim

UNITED STATES  
DEPARTMENT OF THE INTERIOR  
GEOLOGICAL SURVEY

File No. { Washington \_\_\_\_\_  
District \_\_\_\_\_

Grinnell Pump Test. 8-27-55

Time	Engine RPM	Pump RPM	D/W	GPM	Temp OF	Remarks
7:12 P						SWL 301-4" Started Pumping
8:00	700	1250	330-8"	358		
8:30	"	"		362		
9:00	"	"		356		
9:30	"	"		354	74	
10:00	"	"		358		
10:30	"	"		360		
11:00	750	1320	358-2"	500		
11:30	"	"	353-0	480		
	Headings up Record Motor				-	
						SWL 303-8" Started Pumping
1:25						
2:00	750	1350	351-7"	513		
2:30	"	"	351-4	503	74	
3:00	800	1400	367-0	605		
3:30	825	1450	381-7"	692	75	
8-28-55						
10:00 A			303-7"			SWL





UNITED STATES  
DEPARTMENT OF THE INTERIOR  
GEOLOGICAL SURVEY

File No. { Washington \_\_\_\_\_  
District \_\_\_\_\_

Grinnell Pump Test 8-29-55

Time	Engine RPM	Pump RPM	P/W	Gpm	Temp OF	Remarks
10:00A						Started Pumping
11:00	800	1450	378.6	680		
12:00P	800	1500	411.0	752		
12:30	800	"	411.0	750	75	
1:00	"	"	411.0	734		
						Stopped motor
1:30	900	1550	422.6	795		
1:45	"	"	"	"	76	
2:00	"	"	422.5	800		
2:30	"	"	422.0	800	76	
3:00	"	"	422.0	800	76	Water Gauge
3:30	"	"	"	790		
4:00	"	"	"	786		
5:00	925	1590		840		Line stuck
5:30	"	"		"		in hole - no
6:00	"	"		"		flow
7:00	"	1600	439.6	930		Loosened bolts
7:30	"	"	445.0	"		2 turns.
8:00	"	"	444.0	925		
9:00	"	"	438.0	"		
9:30	"	"	444.6	880		
10:00	"	"	"	880		Pulley broke on motor - Shut down
						Pumps off to lower crew's Return. 6 & 7:00
- Electric line stuck in hole. -						

10' of 10" pipe & 15' of 6" pipe from pump.  
meter on 6" line.

490' of 12" pipe <sup>6 steps</sup> to top of house.

508 to section.

Considerable trouble with electric line  
crossing on flanges of pump column.

All d/w cross. made by Bernard Matheley,  
Water Dept., on driven.

Majority of GPM figures from M.B. Starr,  
City Engineer → Average of 15 min check  
with stop watch on meter.

Distance from City well 5 & 6 at water  
plant to new well reported as 745 feet  
by Water Dept.

Well No. 6 pumping 685 gpm

UNITED STATES  
 DEPARTMENT OF THE INTERIOR  
 GEOLOGICAL SURVEY

 File No. { Washington \_\_\_\_\_  
 District \_\_\_\_\_

City well No. 7

Grinnell Pump Test 8-30-55

Time	Engine RPM	Pump RPM	P/w	Gpm	Temp of	Remarks.
						Pulleys changed so as to level pump at higher speed
12:20 Pm			301.12			SWL
1:08			301.28			Using City electric line
1:45			301.22			MP - bearing pump run .70' above top csg. - City use top csg. top csg. 2 1/2' above 15.
2:10						Pump on.
2:18			341	500+		
2:20						Stopped pump
2:30						Pump on
2:36			350	580		
2:44			352.7	"		
2:55	700	1350	352.75	584		
3:00	700	1350	350	569		Wellhead meas.
3:09						Repaired pump
3:12			370	760		
3:30	750	1350	375	760		
4:00	750	1450	379.6	735		
4:30	800	1550	414.6	875		
5:00	825	1600	424	900		
5:30	"	"	425.10	890		
6:00	"	"	426.8	"		
6:30	850	1650	455	970		
7:00	"	"	456	975		
7:30	875	1700	473.2	1017		
8:00	"	"	475	1015		Water Sample



UNITED STATES  
DEPARTMENT OF THE INTERIOR  
GEOLOGICAL SURVEY

Washington  
District  
File No.

8-30-22

No. 5 pump at 300 gpm

Time	Flow Rate	Pressure	Notes
1:50	301.5	202	Start of test
2:00	301.5	202	
2:10	301.5	202	
2:20	301.5	202	
2:30	301.5	202	
2:40	301.5	202	
2:50	301.5	202	
3:00	301.5	202	
3:10	301.5	202	
3:20	301.5	202	
3:30	301.5	202	
3:40	301.5	202	
3:50	301.5	202	
4:00	301.5	202	
4:10	301.5	202	
4:20	301.5	202	
4:30	301.5	202	
4:40	301.5	202	
4:50	301.5	202	
5:00	301.5	202	
5:10	301.5	202	
5:20	301.5	202	
5:30	301.5	202	
5:40	301.5	202	
5:50	301.5	202	
6:00	301.5	202	
6:10	301.5	202	
6:20	301.5	202	
6:30	301.5	202	
6:40	301.5	202	
6:50	301.5	202	
7:00	301.5	202	
7:10	301.5	202	
7:20	301.5	202	
7:30	301.5	202	
7:40	301.5	202	
7:50	301.5	202	
8:00	301.5	202	



UNITED STATES  
DEPARTMENT OF THE INTERIOR  
GEOLOGICAL SURVEY

File No. { Washington \_\_\_\_\_  
District \_\_\_\_\_

Checks in #6 well when testing #7

Grinnell-


ASS		water							
8-29	Time	in	ft	in.					
	Swk at	10:00 am			303-4"				
	#6 pump started at	10:50 am							
	11:00 Am	386-8							
	11:55	390							
	1:00 pm	391	9 1/2						
	2:00	393	1						
	3:00	393	9						
	4:00	394	1						
	4:30	394	6						
	5:00	394	8						
	6:00	394	16						
	7:00	393	9						
	7:30	394	16						
	8:00	395	1						
	8:55	393	9						
	9:30	394	1						
	10:04	394	1						
	11:00	392							
midmto	12:00	391	2						
8-30-33	1:00	390	9						
17:30	8:00	390	1						
	8:05				#6 pump off				
	11:00				45 RESTART				
	11:50	307	1						
	2:30 pm	308	11						
	3:00	310	6						
	3:30	312							
	4:00	313							
	4:30	314	4 1/2						
	6:15	316	5						

UNITED STATES  
DEPARTMENT OF THE INTERIOR  
GEOLOGICAL SURVEY


File No. { Washington .....  
District .....

6:30	316	16										
7:00	317	7										
7:30	318	1										
8:00	318	6										
8:30	315	5										
9:00	313	9										
10:00	312	3										
8-31-55			17 5 577 at 8:00 AM									
8:50	305	11	+ 7 miles <del>later</del>									
9:00	299	4										
1:30	309	4	Bore 5 & 6 running good & less									
Water level measured in #6 with Bathy #5 & #6 pumps was 398'-6".												











8/30/55

Grimmell City well

Log copied from Drillers Notebook

could not locate upper section

JBC

742 - 770	Limestone	1330 - 1375	Shale, Brown
770 - 785	Shale, Gray	1375 - 1398	" Hard
785 - 915	Limestone	1398 - 1560	Brown Lino
915 - 950	" Shale streaks	1560 - 1585	Gray "
950 - 965	Brown Lino	1585 - 1635	Brown "
965 - 980	Limestone	1635 - 1640	Shale-Blue-Green
980 - 985	" Grey shaley	1640 - 1655	Ls. Gray
985 - 995	" " hard	1655 - 1688	Brown Ls.
995 - 1000	" " Shaley	1688 - 1693	Sh.-Blue-Green
1000 - 1025	" "	1693 - 1727	St. Peter SS
1025 - 1042	Brown Ls.	1727 - 1760	Gray Lino
1042 - 1043	Shale, Blue	1760 - 1770	Brown "
1043 - 1085	Limestone, grey (Sharp)	1770 - 1795	Limestone
1085 - 1120	" Brown	1795 - 1922	Ls. - Gray
1120 - 1150	" Sharp	1922 - 1925	Sand
1150 - 1193	"	1925 - 1980	N.R. Sandstone
1193 - 1240	Shale	1980 - 1985	" Some Dolomite
1240 - 1270	" Brown	1985 - 2085	Sandy Dolomite
1270 - 1330	" light	2085 - 2197	Dolomite

Crucio at 2022'

w/L at 830' was 425'

" " 880' " 370'

" " 925' " 429'

w/L at 1900' was 338'-9"

1990' 323'-9"

2030 325'

2055 317'



2197 - 2250	Sand
2250 - 2265	Dolomite
2265 - 2315	Limestone
2315 - 2390	Dolomite
2390 - 2420	" w/shale streaks
2420 - 2495	Dolomite
2495 - 2508	" w/shale streaks
2508 - 2513	Shale
2513 - 2555	Dolomite w/shale streaks
2555 - 2575	Dolomite
2575 - 2595	Sdy. Lime - Brownish
2595 - 2610	Sand - Brownish
2610 - 2620	Sand
2620 - 2625	Sand w/streaks of red
2625 - 2635	Shale
2635 - 2647	Brownish Sand
2647 - 2700	Green Shale Dolomite

Swlat 2180' was 306'

202' 8" liner  
Out at 2702' - 2500

MEMORANDUM

November 21, 1955

To: H. G. Hershey  
From: W. L. Steinhilber  
Subject: Pumping test - Grinnell City Well No. 7

I was notified that pump test had started on November 11 and was to run thru 11/12/55. When I arrived on morning of the 12th, I found the test had been concluded the evening before. The drawdown was excessive and poor water quality was observed.

I located B. Matherly and received the data and a water sample. The data and results are being tabulated and summarized for the files.

Walt



Results of Pumping Test  
Grinnell City Well No. 7  
November 11 and 12, 1955

Name: Grinnell City Well No. 7

Location: SWNW sec. 16, T. 80 N., R. 16 W. (Poweshiek County)

Elevation: 1011 feet above sea level

Contractor: Thorpe Well Company, Des Moines, Iowa

Depth: 2970'

Casing Record: 19" from 0-700' (cemented); 12" from 675 - 2000' (cemented); 10" from 1975 - 2685, swedged in top and bottom (this column was added last to shut-off the Jordan St. Lawrence aquifer -- will be perforated after test); 10" from 2685 to 2700; 8" from 2660 to 2815'; <sup>6"</sup>from 2768' to 2970', bottom 110 ft. perforated.

Test Pump: Turbine, powered by two large diesels. Set at 560'

Discharge measurements and depth to water measurements same as previous tests, made by B. Matherly, Water Superintendent.

Temperature Measurements: made at end of discharge line.

Aquifer Tested. Mt. Simon sandstone

Results: drawdown was extreme - 259' dd. pumping at only 425 g.p.m. after 8 hours. (See results of previous tests on 8/27-30 & 10/12-13/55)

Future plans: Plug to be set at           ft. and casing opposite Jordan sandstone to be perforated from           ft. to           ft.

Data collected by W. L. Steinhilber

Remarks: Matherly made preliminary chloride analysis. Very high, over 2600 p.p.m.

**Results of Pumping Test  
Grinnell City Well No. 7  
November 11 and 12, 1955**

**Name: Grinnell City Well No. 7**

**Location: SWNW sec. 16, T. 80 N., R. 16 W. (Poweshiek County)**

**Elevation: 1011 feet above sea level**

**Contractor: Thorpe Well Company, Des Moines, Iowa**

**Depth: 2970'**

**Casing Record: 19" from 0-700' (cemented); 12" from 675 - 2000' (cemented); 10" from 1975 - 2685, swedged in top and bottom (this column was added last to shut-off the Jordan St. Lawrence aquifer -- will be perforated after test); 10" from 2685 to 2700; 8" from 2660 to 2815'; from 2768' to 2970', bottom 110 ft. perforated.**

**Test Pump: Turbine, powered by two large diesels. Set at 560'**

**Discharge measurements and depth to water measurements same as previous tests, made by B. Matherly, Water Superintendent.**

**Temperature Measurements: made at end of discharge line.**

**Aquifer Tested. Mt. Simon sandstone**

**Results: drawdown was extreme - 259' dd. pumping at only 425 g. p. m. after 8 hours. (See results of previous tests on 8/27-30 & 10/12-13/55)**

**Future plans? Plug to be set at           ft. and casing opposite Jordan sandstone to be perforated from           ft. to           ft.**

**Data collected by W. L. Steinhilber**

**Remarks: Matherly made preliminary chloride analysis. Very high, over 2600 p. p. m.**

UNITED STATES  
 DEPARTMENT OF THE INTERIOR  
 GEOLOGICAL SURVEY

 File No. { Washington .....  
 District .....

Grinnell City Well # 7

Pumping Test 11/11-11/12/55

DATE	Hour	RPM		W/L	D/W	Q (gpm)	Temp.	REMARKS
		Engine	Pump					
11/11	12 N.						63°F	START PUMP
	12:30			391.2	90.2			S.W.L. = 301'
	1:00	750	1400	425.5	124.5	250		
	1:30	800	1490	448.7	147.7	290		Muddy & sand
	2:00	800	1490	448.2	147.2	290		Muddy
	2:30	850	1560	463.3	162.3	350	77°F	clearing
	3:00	"	"	462.8	161.8	345		
	3:30	"	"	462.7	161.7	345	77°F	
	4:00	"	"	462.7	161.7	350		
	4:30	"	"	-		405		
	5:00	"	"	-		405		
	5:30	900	1600	548.3	247.3	405		
	6:00	"	"	548.3	247.3	405		
	6:30	"	"	-		405		
	7:00	"	"	544.6	243.6	405		
	7:30	"	"	544.6	243.6	405		water sample
	8:00	910	1650	560(?)	259.	425	<del>77</del>	little cloudy
	8:00							PUMP off
	8:10			303	257			Recovery
11/12	9:30 a			295				W/L after 13 hrs higher than original STATIC W/L.

 obs: B. Matherly - Town Water Supt.  
 Data collected by W. L. Steinboer  
 SWL = 301'