


213 103  
 IOWA LIMESTONE  
 800 RIVER DR ALDEN IA  
 SAME  
 240

HARDEN

SW 1/4 0 S25 REWARD  
 SE NW 14 89 21 0



- 0 1 BLE SOFT TOPSOIL
- 1 4 BLD SOFT SANDY CLAY
- 4 80 BLD HARD LIMESTONE
- 80 240 DRAIN " "



15	20	8	125	190
12 3/4	20	125	4	140

8"	.322	+ 2	125	127
4"	SEA 40	+ 2	140	142

NEAT	8	130	6.5	405
		9125		

MORTS. INC

6. 40

26

140

40

2

5 10 11

MORTS WELL CO  
 PO 137 CONGER IA  
 JOHN C

1887

TEST PUMP WELL # 73908 4213103 IOWA LIMESTONE

5-10-11

SWL AT START 26 FT FROM GL.

1 MIN	40 FT			
2 MIN	82 FT			
3 MIN	87 FT			
4 MIN	94 FT			
5 MIN	102 FT			
6 MIN	111 FT			
7 MIN	115 FT			
8 MIN	117 FT			
9 MIN	119 FT			
10 MIN	119 FT			
30 MIN	119 FT			
45 MIN	119 FT			
1 HR	119 FT			
2 HR	119 FT			
3 HR	119 FT			
4 HR	119 FT			
5 HR	119 FT			
6 HR	119 FT			
RECOVERY WAS SO FAST THAT				
COULD NOT BRING WELL SOMEWHERE				
UP MORE FAST ENOUGH				

TEST PUMP

40 GPM

2 HP

240 URT

*[Signature]*  
MORTS WELLS CO

