

TOWN OF KANAWHA, I.  
 3-10-58  
 8 hr. TEST

SWL

*Record file*  
 33'6" FROM GROUND LEVEL

TIME	GPM	ORFICE	IN	DD	PL	REMARKS
00:00	0		0	0	33'6"	START
7:00 AM	500	6x4	63"	3'6"	37'	H <sub>2</sub> O STRAW COLOR
9:30 AM	500		63"	3'10"	37'4"	" " "
10:00	500		63"	4'2"	37'8"	" " "
10:30	500		63"	4'4"	37'10"	SLIGHT " " "
11:00	500		63"	4'10"	38'4"	" " "
11:30	500		63"	5'	38'6"	" " "
12:00	500		63"	5'1"	38'7"	" " "
12:30	500		63"	5'4"	38'10"	" " "
1:00 PM	500		63"	5'5"	38'11"	" " "
2:00	500		63"	5'8"	39'2"	a little better
3:00	500		63"	5'11"	39'5"	" " "
3:45	Shut pumps down town had a fire at elevator					
4:00	Started pump and ran pump at about 600 GPM till PL returned to same as PL when pump was shut off. Cut pump back to 400 GPM. P.L. came back immediately to 37'5" (from ground level.)					
4:15 PM	406	6x4	41"	4'5"	37'11"	a little cloudy at
4:30 PM	406		41"	4'7"	38'1"	first.
5:00 PM	406		41"	4'8"	38'2"	clear
5:15 PM	406		41"	4'8"	38'2"	"
5:30 PM	302		22 1/2"	4'1"	37'7"	"
5:45	302		22 1/2"	4'1"	37'7"	"
6:00	200		9 1/2"	3'2"	36'8"	"

RECOVERY IN 30 sec. = 20"  
 FROM THEN ON RATHER SLOW  
 SWL IN 13 HRS AFTER TEST 33'5" FROM GROUND  
 LEVEL