

WELL TEST DATA SHEET

w40116



Layne-Western Company, Inc.

WATER SUPPLY CONTRACTORS

705 SO. DUFF AVE.

AMES, IOWA 50010

Phone 515 232-3563

Job Hampton Airport Well Well no. East of Date Tested 4/2/75
Hampton, Iowa Hanger
 Location Hampton, Iowa Tested By Wayne La Fontaine
 Dia. of Well 12" Driver Int'l Gas
 Depth of Well 68' Pump Used: Column and Shaft 60 x 1 1/2 x 6
 Length of Airline 60' Bowls 2 Stage 12" RKLC
 Non-Pumping Level 8' Manufacturer _____
 Orifice Size 4 x 6 Serial No. _____

Time	Pizometer Reading (in.)	G. P. M.	Air Gauge Reading (feet)	Pumping Level	Drawdown	Disch. Pressure		Total Pumping Head	Remarks
						Lbs.	Feet		
8:00 am			52	8					This test is being made after grout wa done
8:31	15	250	25	35	27				
8:32	15	250	23	37	29				
8:33	15	250	22	38	30				
8:34	15	250	23	37	29				
8:35	15	250	25	35	27				
8:40	15	250	26	34	26				
8:45	15	250	26	34	26				Water cleared right away
8:50	15	250	26	34	26				
8:55	15	250	26	34	26				
9:00	15	250	26	34	26				
9:30	15	250	26	34	26				
10:30	15	250	26	34	26				
11:30	15	250	26	34	26				
RECOVERY									
11:31			48						
11:32			50						
11:33			52	FULL RECOVERY					
11:34			52						
11:35			52						