



CAHOY PUMP SERVICE

SUMNER, IA
Corporate Office
563-578-1130

MARNE, IA
712-781-2030

WELL TEST DATA SHEET

CLIENT: Barnum

WELL: 4

DATE: 1/24/2018

TESTED BY: Lloyd

PUMP MODEL: Theirs

AIRLINE LENGTH: 420'

DIAMETER:

ORIFICE SIZE: 2x4

DEPTH OF WELL:

MOTOR: Theirs

STATIC WATER LEVEL: 93'

GENERATOR USED: **No** Yes

BEGIN HOURS:

END HOURS:

STEP-RATE TEST

CONSTANT RATE TEST

PRE-TREATMENT

POST -TREATMENT

MEASUREMENT TAKEN FROM THE TOP OF THE WELL CASING WHICH IS 3' 3" FROM EXISTING GROUND/FLOOR LEVEL.

