



Rembrant Well #8 (04/02/2018 - 04/03/2018)		
24 hour test pumping with recovery status		
600 GPM/ 24 Hours		
Time		Static depth- 262' 3"
3:15pm	1 min	311' 5"
	2 min	313' 0"
	3 min	313' 5"
	5 min	314' 3"
	7 min	314' 9"
	10 min	315' 5"
3:35pm	20 min	315' 7"
4:05pm	50 min	318' 9"
4:25pm	70 min	319' 2"
4:55pm	100 min	320' 0"
5:55pm		320' 5"
6:55pm		320' 9"
7:55pm		321' 1"
8:55pm		321' 1"
9:55pm		321' 2"
10:55pm		319'7"
11:55pm		319' 6"
12:55am		319' 5"
1:55am		319' 6"
2:55am		321' 1"
3:55am		321' 1"
4:55am		321' 1"
5:55am		321' 1"
6:55am		321' 3"
7:55am		321' 2"
8:55am		322' 8"
9:55am		321' 9"
10:55am		321' 9"
11:55am		321' 9"
12:55pm		321' 9"
1:55pm		321' 9"
2:55pm		321' 9"
3:55pm		321' 9"
Start Recovery Break		
3:56pm		268' 3"
4:06pm		266' 2"
4:16pm		265' 5"
4:26pm		265' 0"
4:36pm		264' 8"
4:46pm		264' 7"
4:56pm		264' 6"
5:56pm		264' 4"
6:56pm		264' 3"
7:56pm		264' 2"
8:56pm		264' 2"
9:56pm		264' 1"
10:56pm		264' 0"
11:56pm		264' 0"
12:56am		264' 0"
1:56am		264' 0"

Sand Test	
Time	Sand/ No Sand
8:05am-8:55am	No Sand
10:55am-11:55am	No Sand
1:55pm-2:55pm	No Sand

