



PUMPING TEST  
WELL TEST DATA SHEET

64074 -



# Layne-Western Company, Inc.

PROFESSIONAL SERVICES FOR WATER SYSTEMS

4430 Commercial Avenue • Omaha, Nebraska 68110 • Phone: 402/451-2388

Job CITY OF LAKE VIEW Well No. 4 Date Tested 4-17-93  
 Location LAKE VIEW, IOWA Tested By DAVE DEAVER/LYLE PORTER  
 Dia. of Well 12" Driver GENERATOR  
 Depth of Well 72.1' FROM TOP OF PITLESS Pump Used: \_\_\_\_\_ Column and Shaft \_\_\_\_\_  
 Length of Airline \_\_\_\_\_ Bowls SUBMERSIBLE  
 Non-Pumping Level 20.0' FROM TOP OF PITLESS Manufacturer \_\_\_\_\_  
 Orifice Size 6' x 5" Serial No. \_\_\_\_\_

Time	Piezometer Reading (in.)	G.P.M.	Air Gauge Reading (feet)	Pumping Level	Drawdown	Disch. Pressure		Total Pumping Head	Remarks
						Lbs.	Feet		
1 min.		653		24.5'	4.5'				
2				24.8'	4.8'				
3				25.0'	5.0'				
4				25.2'	5.2'				
5				25.3'	5.3'				
6				25.5'	5.5'				
7				25.5'	5.5'				
8				25.5'	5.5'				
9				25.5'	5.5'				
10				25.5'	5.5'				
12				25.5'	5.5'				
14				25.5'	5.5'				
16				25.5'	5.5'				
18				25.5'	5.5'				
20				25.6'	5.6'				
25				25.7'	5.7'				
30				25.7'	5.7'				
35				25.8'	5.8'				
40				25.8'	5.8'				
45				25.8'	5.8'				
50				25.8'	5.8'				
55				25.8'	5.8'				
1 hour				25.8'	5.8'				
1.5				25.8'	5.8'				
2				25.8'	5.8'				





WELL TEST DATA SHEET

64074 -

Layne-Western Company, Inc.

PROFESSIONAL SERVICES FOR WATER SYSTEMS

4430 Commercial Avenue • Omaha, Nebraska 68110 • Phone: 402/451-2388

Job CITY OF LAKE VIEW Well No. 4 Date Tested 4-18-93
Location LAKE VIEW, IOWA Tested By DAVE DEAVER/LYLE PORTER
Dia. of Well 12" Driver
Depth of Well 72.1' FROM TOP OF PITLESS Pump Used: Column and Shaft
Length of Airline Bowls
Non-Pumping Level 20.0' FROM TOP OF PITLESS Manufacturer
Orifice Size Serial No.

Table with 10 columns: Time, Piezometer Reading (in.), G.P.M., Air Gauge Reading (feet), Pumping Level, Drawdown, Disch. Pressure (Lbs., Feet), Total Pumping Head, Remarks. Rows include 1 MIN. and 1 HOUR intervals.