



# Test of Well Report

94293

Job # LH20-603

Customer Name Lake Panorama Assoc.

Date 6/17/2020

Test Information							
Well No:	2	Well Location	W RV Road, Panora, IA			Tested By	Anthony Herbst
Dia. Orifice	x	Static Level	440 ft	in	Well Depth	ft	
Drilled by		Length of Airline	606	Gauge to Ground Level:	ft	in	
Pump Set to Discharge Nozzle	606 ft	To Tail Pipe	ft				

Reading No:	Time	Inches on orifice	GPM	Alt. Ga. in Feet	Pumping Level Ft.	Drawdown in Feet	Back Pressure	Specific Capacity	Water Appearance: clear, cloudy, murky muddy, sandy, temp., odor
									6/17/20 - con't
1	6:00 AM		825	112.0	494.0	54.0	38	15.28	
2	7:00 AM		825	110.0	496.0	56.0	38	14.73	Clear
3	8:00 AM		825	110.0	496.0	56.0	38	14.73	
4	9:00 AM		825	107.0	499.0	59.0	38	13.98	
5	10:00 AM		825	105.0	501.0	61.0	38	13.52	
6	11:00 AM		825	105.0	501.0	61.0	38	13.52	Clear
7	12:00 PM		825	105.0	501.0	61.0	38	13.52	
8	1:00 PM		825	105.0	501.0	61.0	38	13.52	
9	2:00 PM		825	105.0	501.0	61.0	38	13.52	
10	3:00 PM			103.0	503.0	63.0	38	0.00	
11	4:00 PM		825	105.0	501.0	61.0	38	13.52	
12	5:00 PM		825	105.0	501.0	61.0	38	13.52	
13	6:00 PM		825	105.0	501.0	61.0	38	13.52	
14	7:00 PM		825	108.0	498.0	58.0	38	14.22	
15	8:00 PM		825	107.0	499.0	59.0	38	13.98	
16	9:00 PM		825	107.0	499.0	59.0	38	13.98	
17	10:00 PM		825	107.0	499.0	59.0	38	13.98	
18	11:00 PM		825	107.0	499.0	59.0	38	13.98	
19	12:00 AM		825	107.0	499.0	59.0	38	13.98	6/18/20

Test of Well Report

Customer Name		Lake Panorama Assoc.					Orifice Size		x				
Static Water Level		440		Length of Airline		606		Pump Set		606		Page #	2
Reading No:	Time	Inches on orifice	GPM	Alt. Ga. in Feet	Pumping Level Ft.	Drawdown in Feet	Back Pressure	Specific Capacity	Water Appearance: clear, cloudy, murky muddy, sandy, temp., odor				
20	1:00 AM		825	107.0	499.0	59.0	38	13.98					
21	2:00 AM		825	107.0	499.0	59.0	38	13.98					
22	3:00 AM		825	107.0	499.0	59.0	38	13.98					
23	4:00 AM		825	107.0	499.0	59.0	38	13.98					
24	5:00 AM		825	107.0	499.0	59.0	39	13.98					
25	6:00 AM		825	107.0	499.0	59.0	38	13.98					
26	7:00 AM		825	106.0	500.0	60.0	39	13.75					
27	8:00 AM		825	105.0	501.0	61.0	39	13.52					
28	9:00 AM		825	104.0	502.0	62.0	39	13.31					
29	10:00 AM		825	104.0	502.0	62.0	39	13.31					
30	11:00 AM		825	103.0	503.0	63.0	39	13.10					
31	12:00 PM		825	105.0	501.0	61.0	39	13.52					
32	1:00 PM		825	103.0	503.0	63.0	39	13.10	Clear				
33	2:00 PM		825	102.0	504.0	64.0	39	12.89					
34	2:45 PM		825	102.0	504.0	64.0	39	12.89	Clear				
35	3:15 PM		0	145.0	461.0	21.0	0	0.00	Recovery				
36	3:45 PM		0	147.0	459.0	19.0	0	0.00					
37	4:15 PM		0	148.0	458.0	18.0	0	0.00					
38	4:45 PM		0	150.0	456.0	16.0	0	0.00					
39	5:15 PM		0	151.0	455.0	15.0	0	0.00					
40	5:45 PM		0	152.0	454.0	14.0	0	0.00					
41													
42													
43													
44													
45													
46						-440.0		0.00					
47						-440.0		0.00					
48													
49													
50								13.98					